



City Commission Work Session

Agenda

December 14, 2023 @ 1:00 PM

City Hall Commission Chambers
401 S. Park Avenue

welcome

Agendas and all backup material supporting each agenda item are accessible via the city's website at cityofwinterpark.org/meetings/ and include virtual meeting instructions.

assistance & appeals

Persons with disabilities needing assistance to participate in any of these proceedings should contact the City Clerk's Office ([407-599-3277](tel:407-599-3277)) at least 48 hours in advance of the meeting.

"If a person decides to appeal any decision made by the Board with respect to any matter considered at this hearing, a record of the proceedings is needed to ensure that a verbatim record of the proceedings is made, which record includes the testimony and evidence upon which the appeal is to be based." (F.S. 286.0105).

please note

Times are projected and subject to change.

1. Meeting Called to Order**2. Discussion Item (s)**

- a. Integrated Resource Plan (IRP) Study

2 Hours

3. Adjournment



City Commission

agenda item

item type

Discussion Item (s)

meeting date

December 14, 2023

prepared by

Victoria Tabor, Administrative Coordinator II

approved by

Randy Knight, City Manager

subject

Integrated Resource Plan (IRP) Study

motion | recommendation**background****strategic objectives****alternatives | other considerations****fiscal impact****attachments**

1. IRP Revised Results Presentation
2. 23.12.07 Quanta Technology CWP IRP Report Final
3. 23.11.11 Key Assumptions-Final
4. SUMMARY OF EDITS AND TIMELINE (003)



**QUANTA
TECHNOLOGY**
A QUANTA SERVICES COMPANY

December 2023

City of Winter Park Final Revised Report Presentation





Agenda




- **Purpose**
- **Method**
- **Original Scenarios**
- **Added Scenarios**
- **Definitions**
- **Results**
- **Roadmap**



Purpose of Integrated Resource Plan Study



What is the cost & feasibility of reaching City's clean energy goals?



To support clean energy in the City of Winter Park.





Study Method: How Resource Portfolios Were Identified and Evaluated

- 1 Define scenarios so they describe a range of plausible future conditions.
- 2 Identify baseline assumptions for each scenario.
- 3 Define least cost-expansion plan for each scenario.
- 4 Develop a list of possible portfolios based on results.
- 5 Adjust portfolios as needed.
- 6 Select the best performing portfolio, and identify no-regret, or limited regret strategies across the future scenarios.



Outline of Three Base Targets Defined in Original Study Scope

- Target 1: 100% Renewable Energy Supply by 2050
- Target 2: 100% Net-Zero Carbon by 2050 Target
- Target 3: 80% Renewable by 2035 and 100% by 2050



Three Targets – Each Expanded with Multiple Scenarios

Total of 15 Different Scenarios

Scenario Count 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15

Scenarios

Scenario Element	100% Renewable by 2050						Net-Zero Carbon by 2050					80% Renewable by 2035 and 100% by 2050			
	1A	1B	1C	1D	1E	1F	2A	2B	2C	2D	2E	3A	3B	3C	3D
2050 renewable target	100%	100%	100%	100%	100%	100%	-			-	-	100%	100%	100%	100%
2050 net-zero carbon target							100%	100%	100%	100%	100%				
2035 renewable energy target												80%	80%	80%	80%
Load forecast	Expected	High	Expected	Expected	Expected	Expected	Expected	High	Expected	Expected	Expected	Expected	Expected	Expected	Expected
Natural gas fuel price forecast	Expected	Expected	Expected	Expected	High	Low	Expected	Expected	Expected	High	Low	Expected	Expected	High	Low
Distributed solar + storage	Expected	High	Low	Expected	Expected	Expected	Expected	High	Low	Expected	Expected	Expected	Expected	Expected	Expected
New Solar PV on City Rooftops and Land	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Electric-vehicle growth	Expected	High	Low	Expected	Expected	Expected	Expected	High	Low	Expected	Expected	Expected	Expected	Expected	Expected
REC pricing	N/A	N/A	N/A	N/A	N/A	N/A	Expected	Low	High	Expected	Expected	N/A	N/A	N/A	N/A
Developer cost of capital for generation	8.00%	8.00%	8.00%		8.00%	8.00%	8.00%	8.00%	8.00%	8.00%	8.00%	8.00%		8.00%	8.00%
CWP cost of debt for generation				3.50%									3.50%		
Extra capacity for storm resiliency	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No



Study Scope Was Expanded

- After presenting results, the City requested additional three additional scenarios and analysis, including:
 - Scenario 3E – to assess the costs differences of eliminating the distributed solar Photovoltaic (PV) additions from Scenario 3A
 - Assess the costs of additional resources required for the portfolio defined in Scenario 3A should solar PV resources become unavailable for a multi-day period, such as during a hurricane or other severe weather event. This was done with:
 - New Scenario 4A - assuming only batteries were used
 - New Scenario 4B - assuming legacy Florida fossil units would be used



Three New Scenarios

Total of 18 Different Scenarios

Scenario Count	16	17	88
Scenarios			
Scenario Element	80% by 2035 and 100% by 2050	80% by 2035 and 100% by 2050 Plus Storm Resiliency	
	3E	4A	4B
2050 renewable target	100%	-	
2035 renewable energy target	80%	80%	80%
Load forecast	Expected	Expected	High
Natural gas fuel price forecast	Expected	Expected	Expected
Distributed solar + storage	Expected	Expected	High
New Solar PV on City Rooftops and Land	No	Yes	Yes
Electric-vehicle growth	Expected	Expected	High
REC Pricing	N/A	N/A	N/A
Developer cost of capital for generation	8.00%	8.00%	8.00%
CWP cost of debt for generation	N/A	N/A	N/A
Extra Capacity for Storm Resiliency	No	Yes with Batteries	Yes, with old fossil units



Definitions



Revenue requirement

Required utility revenue needed to pay for all capital, operational and maintenance costs



Present value of revenue requirement

The annual revenue requirement after it has been discounted to a common based year



Levelized cost of energy

The present value of the stream of annual of energy costs divided by the stream of annual MWh consumed.




PVRR Results for All 18 Scenarios Indicate that Targets are Feasible

- Results for first 20 years of all scenarios are very close to the projected growth in costs of existing CWP fossil supplies.
- Results for 28 years show more variation due to technologies added in the later years of the study.





Original Focus on Scenario 3A Shifted to 3D as Ukraine Driven Natural Gas Price Spikes Returned to Historical Ranges






Summary of Financial Results - PVRR and LCOE



Scenario	3D
PV of revenue requirements (\$M)	
• Based on 20 years of costs to 2042	\$442
• Based on 28 years of costs to 2050	\$649
Levelized cost of energy (\$/MWh), no escalation	
• Based on 20 years of costs to 2042	\$79
• Based on 28 years of costs to 2050	\$92



Roadmap Next Steps






Roadmap (Short-term)

Primary focus: Alignment, definition, goal setting/validation

Timeframe: July 2023 – December 2023

Actions	Projects
• Define clear target for CWP's clean energy supply. • Start CWP IRP program.	• Establish multiple interim targets for renewable contributions before 2050 • A program manager will likely be needed to coordinate all aspects of reaching the goal



Short



Mid



Long



Roadmap (Mid-term)

Primary focus: Customer DR/energy efficiency, solar expansion with storage


Timeframe: Next 18 Months by June 2025

Actions

- Develop TOU, DR and EE programs.
- Prioritize more utility-scale renewable purchases over solar on city rooftops.
- Explore CWP utility bill financing.
- Update resource plan with using new data.

Projects

- Complete load research study for input to TOU, DR and EE programs.
- Complete a study of all CWP assets for solar/storage incorporation and prioritization.
- Complete a CWP-specific EV adoption study.
- Explore City financing for customer rooftop solar and storage.
- Complete a revised IRP with a technology maturity assessment once EE and DR programs and load research are complete.





Roadmap (Long-term)

Primary focus: Implementation of Programs (EE, TOU)

Timeframe: Next 48 Months by June 2027

Actions	Projects
• Create plan for CWP vehicle electrification.	• Complete a study and plan for the electrification of all CWP-owned vehicles.
• Implement EE, DR, TOU and NEM changes.	• Implement a robust set of EE and DR programs. • Create and implement TOU rates. • Change the NEM rate credited to customers.
• Update IRP and technology maturity assessments.	• Commit to revising and updating the CWP IRP every 3 - 4 years and update technology maturity assessment.




Short



Mid



Long





Follow Us



919-334-3000



quanta-technology.com




info@quanta-technology.com



linkedin.com/company/quanta-technology/



twitter.com/quantatech





Additional Slides



Definition and Assumptions

Term	Definition
Renewable	All energy originates from some form of renewable technology
Renewable energy	• Energy is generated only from technologies that are considered to be renewable, including: wind, solar, ocean energy, geothermal, hydroelectricity, technologies that burn fuels derived from biomass and green hydrogen (i.e., hydrogen generated from processes that use water and renewable energy). • Biomass is a solid or gaseous renewable energy resource derived from plant- and algae-based materials (e.g., crop wastes, microalgae, urban wood waste, food waste etc.). • Hydroelectricity is a renewable technology but is treated differently than other forms of renewable energy in some states due to its other impacts on the environment.
Net-zero carbon	Net zero refers to a state in which the greenhouse gases going into the atmosphere are balanced by removal out of the atmosphere. Generally, utilities plan to achieve net zero by both reducing their carbon emissions and acquiring carbon offsets, carbon credits to offset any remaining carbon emissions.
Zero carbon	• All energy is created with technologies that do not emit carbon into the atmosphere • Real Zero™ is a new term just recently invented and trademarked by FPL and is identical in definition to zero carbon. • For electric generation, zero carbon energy resources include nuclear and renewable technologies that do not emit carbon to the atmosphere.



QUANTA
TECHNOLOGY

REPORT

City of Winter Park 100% Renewable Initiative Final Report



PREPARED FOR

City of Winter Park

DATE

December 7, 2023
(Version 7.0)

PREPARED BY

Michael Mount
MMount@quanta-technology.com

Hisham Othman
Hothman@quanta-techonology.com

Diana Prkacin
DPrkacin@quanta-technology.com

Jesus Gonzalez
JGonzalez@quanta-Technology.com

QUANTA TECHNOLOGY, LLC

4020 Westchase Boulevard, Suite 300, Raleigh, NC 27607 USA

RALEIGH (HQ) | TORONTO | SAN FRANCISCO BAY AREA | SOUTHERN CALIFORNIA | CHICAGO

www.Quanta-Technology.com

Quanta Technology, LLC is a wholly-owned subsidiary of Quanta Services, Inc. (NYSE: PWR)

© 2023 QUANTA TECHNOLOGY, LLC | CONFIDENTIAL & PROPRIETARY

Page 23 of 108



CONFIDENTIAL/PROPRIETARY: This document contains trade secrets and/or proprietary, commercial, or financial information not generally available to the public. It is considered privileged and proprietary to Quanta Technology, LLC and is submitted with the understanding that its contents are specifically exempted from disclosure under the Freedom of Information Act [5 USC Section 552 (b) (4)] and shall not be disclosed by the recipient (whether it be Government [local, state, federal, or foreign], private industry, or non-profit organization) except with the written permission of Quanta Technology and shall not be duplicated, used, or disclosed, in whole or in part, for any purpose except to the extent provided in the contract. The contents of this document shall be treated by City of Winter Park in a manner consistent with the designation.

DISCLAIMER: This report is prepared by Quanta Technology, LLC. Quanta Technology was engaged by City of Winter Park ("the Client/s"). The report is to the parameters set by the Client/s and contained in the engagement documentation between Quanta Technology and the Client/s. Data for this report was provided by the Client/s, and Quanta Technology bears no responsibility if the data was incorrect. This report is solely for the use of the Client/s and is not intended to and should not be used or relied upon by anyone else unless their use is requested by the Client/s and approved in writing by Quanta Technology before any dissemination or use. If any other expected users are listed in the original engagement documentation, Quanta Technology shall be deemed to have accepted that those users are included as acceptable recipients. Quanta Technology does not accept any duty of care to any other person or entity other than the Client/s. This report has been prepared for the purpose set out in the engagement documentation between Quanta Technology and the Client/s. Any other recipients other than those approved by Quanta Technology should seek independent expert advice as this report was not prepared for them or for any other purpose than that detailed in the engagement terms with the Client/s and cannot be relied upon other than for this. Information contained in this report is current as of the date of this report and may not reflect any event or circumstances which occur after the date of this report. All queries related to the content or any use of this report must be addressed to the Client/s.

Report Contributors:

- Michael Mount
- Hisham Othman
- Diana Prkacin
- Khoi Vu
- Jesus Gonzalez

VERSION HISTORY:

Version	Date	Description
1.0	03/06/2023	Draft submission for CWP review
2.0	03/10/2023	Draft final submission for CWP Review
3.0	05/04/2023	Final submission of Revision 1 of Report
4.0	9/13/2023	Draft for review of revised and added analysis
5.0	10/14/2023	Corrected upper and lower fuel scenario results and added text
6.0	11/05/2023	Final Submission of Revision 2 of Report
7.0	12/07/2023	Final Submission of Revision 3 of Report with new Appendix I and delayed milestone dates in recommended roadmap





TABLE OF CONTENTS

1	EXECUTIVE SUMMARY	7
2	PROJECT SCOPE	9
2.1	Overview	9
2.2	Scope of Work	10
3	PROBABILISTIC IRP MODELING OVERVIEW	12
3.1	Philosophy and Approach.....	12
3.2	pIRP Model Overview	13
4	FORECASTS AND OTHER DATA INPUTS	18
4.1	Overview	18
4.2	Gross Customer Usage	18
4.3	Distributed Solar and Storage	23
4.4	Electric Vehicles.....	24
4.5	Generation Technologies and Battery Storage.....	27
4.6	Energy Efficiency and Demand Response.....	30
4.7	Fuel Price.....	32
4.8	Renewable Energy Credits.....	34
4.9	Financial Assumptions.....	35
5	SCENARIO DESCRIPTIONS.....	37
5.1	Targets and Scenarios	37
6	COST AND FEASIBILITY COMPARISONS	42
6.1	Target 1: 100% Renewable Energy Supply by 2050.....	42
6.2	Target 2: 100% Net-Zero Carbon by 2050 Target.....	46
6.3	Target 3: 80% Renewable by 2035 and 100% by 2050.....	49
6.4	Target 4: 80% Renewable by 2035, 100% by 2050, and Storm Resiliency	52
6.5	Summary of All Scenarios	54
7	CONCLUSIONS AND RECOMMENDED ROADMAP	58
7.1	Conclusions	58
7.2	Recommended Roadmap.....	58
7.2.1	Next Three Months (May 2023–July 2023)	59
7.2.2	Next 18 Months (August 2023–February 2025)	60
7.2.3	Next 48 Months (March 2025–April 2027).....	61
7.2.4	Beyond 48 Months (Beyond April 2027).....	62



APPENDIX A: TERMS AND DEFINITIONS	63
APPENDIX B: LIST OF ABBREVIATIONS AND ACRONYMS.....	65
APPENDIX C: BATTERY LIFECYCLE CONSIDERATIONS	67
APPENDIX D: NREL PVWATTS SOLAR PRODUCTION ESTIMATE.....	68
APPENDIX E: RESIDENTIAL ROOFTOP SOLAR AND BATTERY FORECASTS	70
APPENDIX F: FORECAST OF ROOFTOP AND GROUND MOUNT SOLAR PV ON CWP-OWNED PROPERTY.....	71
APPENDIX G: RESIDENTIAL LDV EV FORECASTS.....	72
APPENDIX H: ANNUAL SCHEDULE OF CAPACITY PURCHASES	73
APPENDIX I: DAILY ENERGY SOURCES	76

List of Figures

Figure 1. pIRP Process Overview	13
Figure 2. Zonal Representation of the Power System	14
Figure 3. Time Buckets Representation of Time.....	14
Figure 4. pIRP Modeling Capability.....	15
Figure 5. pIRP Sample Output 1.....	16
Figure 6. pIRP Sample Output 2.....	16
Figure 7. pIRP Sample Output 3.....	17
Figure 8. Historical Annual CWP Energy Consumption and System Peak Demand	19
Figure 9. CWP Annual System Load Factor.....	20
Figure 10. Forecast of Florida Utility Growth Rates.....	21
Figure 11. CWP Forecasted Annual Energy Consumption	22
Figure 12. CWP Forecasted System Peak Demand	22
Figure 13. Resident and Commuter Annual EV-LDV Charging Energy: Expected Scenario.....	26
Figure 14. Annual Resident and Commuter EV-LDV Charging Energy.....	26
Figure 15. Projections of Generation and Storage Technologies Installed Costs.....	29
Figure 16. TYSP Utilities: Average Fuel Price of Reporting Electric Utilities.....	32
Figure 17. Ten Year History of Natural Gas Henry Hub Spot Price	33
Figure 18. Natural Gas Price Forecast at Henry Hub	33
Figure 19. REC Price Forecast.....	35
Figure 20. Comparison of Renewable Energy Results for the Two Renewable-Based Targets.....	42
Figure 21. Capacity Additions for Scenario 1A.....	43
Figure 22. Annualized Cost of Energy and LCOE: Scenario 1A Based on 2023–2050	45
Figure 23. Annualized Cost of Energy and LCOE: Scenario 1A Based on 2023–2042	46
Figure 24. Capacity Additions for Scenario 2A.....	47
Figure 25. Annualized Cost of Energy and LCOE: Scenario 2A Based on 2023–2050	48
Figure 26. Annualized Cost of Energy and LCOE: Scenario 2A Based on 2023–2042	48
Figure 27. Capacity Additions for Scenario 3A.....	49



Figure 28. Annualized Cost of Energy and LCOE: Scenario 3A Based on 2023–2050	50
Figure 29. Annualized Cost of Energy and LCOE: Scenario 3A Based on 2023–2042	50
Figure 30. Annualized Cost of Energy and LCOE: Scenario 3D Based on 2023–2042	51
Figure 31. Annualized Cost of Energy and LCOE: Scenario 3D Based on 2023–2042	51
Figure 32. Annualized Cost of Energy and LCOE: Scenario 4A (Battery Capacity) Based on 2023–2050.....	52
Figure 33. Annualized Cost of Energy and LCOE: Scenario 4A (Battery Capacity) Based on 2023–2042.....	53
Figure 34. Annualized Cost of Energy and LCOE: Scenario 4B (Old Fossil Capacity) Based on 2023–2050 .	53
Figure 35. Annualized Cost of Energy and LCOE: Scenario 4B (Old Fossil Capacity) Based on 2023–2042 .	54
Figure 36. Summary of 28-Year and 20-Year PVRR Results for All Scenarios	55
Figure 37. Comparison of Annual Power Costs for Scenario 3D and CWP Escalated	56
Figure 38. Illustrative Annual Renewable Targets	60
Figure 39. PVWatts Calculator	68
Figure 40. PVWatts Information and Metrics.....	69
Figure 41. Energy Sources by Hour for Average Summer Week-Day - Scenario 1A, Year 2042	76
Figure 42. Energy Sources by Day for Average Summer Week-Day - Scenario 1A, Year 2042	76

List of Tables

Table 1. 2022 TYSP: Estimated Number of EVs	24
Table 2. 2022 TYSP: Estimates EV Annual Charging Consumption (GWh)	25
Table 3. Annual Energy Consumption Per EV (kWh)	25
Table 4. Generation and Storage Technologies Costs	28
Table 5. Solar PV Costs for Key Milestone Years (Installed Cost–\$/kW)	30
Table 6. Battery Storage Costs for Key Milestone Years (Installed Cost–\$/kWh)	30
Table 7. Primary Financial Assumptions	36
Table 8. Details for Scenarios Focused on Targets 1 and 2.....	39
Table 9. Details for Scenarios focused on Targets 3 and 4	40
Table 10. Developer Weighted Average Cost of Capital	41
Table 11. Capacity and Costs of Solar PV on CWP Owned Buildings and Vacant Land	41
Table 12. Three-Month Recommendations.....	59
Table 13. 18-Month Recommendations	60
Table 14. 48-Month Recommendations	62
Table 15. Report Terms	63
Table 16. Report Abbreviations and Acronyms	65
Table 17. Residential Rooftop Solar PV And Battery Forecasts	70
Table 18. Forecast Of Rooftop And Ground Mount Solar PV On CWP-Owned Property.....	71
Table 19. Residential LDV EV Forecasts	72
Table 20. Scenario 1A: Annual Capacity Purchases (MW)	73
Table 21. Scenario 2A: Annual Capacity Purchases (MW)	74
Table 22. Scenario 3A: Annual Capacity Purchases (MW)	75



1 EXECUTIVE SUMMARY

The City of Winter Park (CWP) is located in Central Florida adjacent to Orlando in Orange County. Winter Park's vision is a city of arts and culture, cherishing its traditional scale and charm while building a healthy and sustainable future for all generations. CWP owns its electric distribution assets, and its utility supplies electricity to approximately 14,276 customers. CWP does not generate power but has contracts with the Florida Municipal Power Association (FMPA) and Orlando Utilities Commission (OUC) to purchase approximately 100 MW of power yearly and approximately 10 MW from Covanta, which derives power from burning waste.

CWP is committed to a sustainable future and has created a sustainability action plan (SAP) that calls for reducing greenhouse gas emissions (GHG) and targets all electricity consumption from renewable-fueled resources. Specifically, three primary targets were defined for evaluation as possible CWP goals for evolving toward a sustainable electric energy supply. The three potential targets under consideration for the future CWP energy supply include:

- **Target 1:** 100% renewable energy supply by 2050
- **Target 2:** 100% net-zero carbon energy supply by 2050
- **Target 3:** 80% renewable energy supply by 2035 and then 100% by 2050

Target 4 was also defined to assess the impacts of adding additional capacity to the portfolios identified by Target 3 to replace solar generation assumed to be lost during severe multiday storm events.

It is important to note that while a net-zero carbon scenario was analyzed as Target 2, CWP is primarily focused on roadmaps based upon true 100% renewable or carbon-free targets. Therefore, primary conclusions and roadmap considerations are centered around 100% renewable paths (Targets 1 and 3).

Each target was further analyzed by way of scenario considerations. A scenario in this context is a set of future conditions that collectively describe the external environment/conditions under which supply options are to be assessed. In the case of a resource plan, a scenario description includes a multi-year forecast of external drivers or assumptions important to the analysis, including load forecasts, EV growth, costs for renewables and battery storage, distributed solar and storage, the cost for natural gas fuel, energy efficiency (EE) and demand response (DR) forecasts, and financial assumptions.

To better account for future conditions, Quanta Technology used a planning methodology that considers ranges of plausible future conditions founded on variations of multiple scenarios rather than analysis on a single scenario associated with a target. Therefore, the three base targets were expanded into a total of 18 different scenarios:

- Six focused on achieving Target 1 (100% renewable by 2050)
- Five focused on achieving Target 2 (100% net-zero carbon by 2050)
- Five focused on achieving Target 3 (80% renewable supply by 2035 and then 100% by 2050)
- Two focused on Target 4 (80% renewable energy supply by 2035, 100% by 2050, with added capacity for storm resiliency)



This analysis indicates that CWP's adoption of a path toward 100% renewables can be accomplished for a reasonable cost of power for the next 20 years. However, beyond the next 20 years (i.e., during the last 6 years analyzed in this report from 2043–2050), the technology selection and the costs remain understandably more uncertain and, based on the technology options and costs assumed in this study, could bring a substantial increase in CWP's power costs. This rapid rise in costs near the end of the study period was driven by assumptions on technology costs, which resulted in a sharp increase in cost during the final years of the study.

Quanta Technology believes that additional cost-effective technologies will be available well before 2043. The power industry is expending considerable time and money on identifying options that could deliver lower-priced energy sources, including offshore wind, long-term energy storage technologies, and new technologies for geothermal energy, among others. While the costs projected in the last 6 years of the study are high, based on the current assumptions, the costs before 2043 are comparable to projected CWP costs and could be lower. CWP should not avoid adopting its renewable targets because of costs that are not expected to occur for over 20 years. CWP should regularly reevaluate its targets and plans for its electric energy supply. Should continuing on a path to 100% renewable prove too costly in future years, CWP can adjust accordingly.

A recommended roadmap was developed and principally centered around the following:

- **Short-term (May–July 2023):** Focusing on alignment, definition, and goal setting/validation, which includes defining and committing to a clean energy supply target and establishing multiple interim targets for renewable contributions along the path to 2050.
- **Mid-term (August 2023–February 2025):** Focusing on designing customer EE and DR programs, time of use (TOU) rates, and prioritizing utility-scale renewable purchases over solar for city assets.
- **Long-term (March 2025–April 2027):** Focusing on implementing EE and DR programs, TOU rates, and changing the net energy metering (NEM) rate credited to the customer to a cost-based TOU rate.

A complete list of the recommended activities and projects in the roadmap is included in Section 7.2. Appendix A provides definitions of terms used in this report, and Appendix B provides a list of acronyms used in this report.



2 PROJECT SCOPE

2.1 Overview

The City of Winter Park (CWP) is 10 square miles with over 30,000 residents. CWP's Electric Utility Department supplies electricity to approximately 14,276 customers (12,048 residential properties and 2,228 commercial customers). CWP does not generate power but has contracts with the Florida Municipal Power Association (FMPA) and Orlando Utilities Commission (OUC) to purchase approximately 100 MW of power yearly. In addition, CWP purchases approximately 10 MW of power from Covanta, which derives power from burning municipal waste as its fuel. Municipal waste combustion reduces contributions to landfills, but the process emits carbon dioxide and other harmful emissions into the atmosphere and is neither a renewable nor carbon-free generation technology. In 2023, CWP will also purchase 20 MW of solar energy through its partnership with the FMPA.

CWP is committed to a sustainable future and has passed resolutions to promote its commitment. On January 14, 2008, the CWP City Commission (City Commission) passed a resolution stating that CWP would pursue measures to become a certified Green Local Government through the Florida Green Building Coalition (FGBC). In 2011, CWP was officially certified as a Green Local Government at the Gold level. As part of those efforts, CWP has created a sustainability action plan (SAP) that calls for reducing greenhouse gas emissions (GHG) and targets all electricity consumption from renewable-fueled resources by 2035.

CWP defines sustainability as “responsible and proactive decision-making that minimizes negative impact and maintains a balance between social, environmental, and economic growth to ensure a desirable environment for all species now and into the future.” CWP believes its efforts to invest in sustainability will bring numerous benefits, increasing quality of life, reducing dependence on fossil fuels, protecting and enhancing the environment, and realizing economic value and savings.

CWP contracted Quanta Technology to conduct a study that outlines a roadmap and a feasible action plan for CWP to reach its sustainability objectives. CWP stressed the importance of creating a realistic, practical plan with feasible implementation options. The study was centered around the assessment of four potential targets under consideration for the future CWP energy supply:

- **Target 1:** 100% renewable energy supply by 2050
- **Target 2:** 100% net-zero carbon energy supply by 2050
- **Target 3:** 80% renewable energy supply by 2035 and then 100% by 2050
- **Target 4:** 80% renewable energy supply by 2035, 100% by 2050, with added capacity for storm resiliency

Net-zero carbon refers to a state in which the greenhouse gases going into the atmosphere are balanced by removing carbon from the atmosphere. Generally, utilities plan to achieve net zero by reducing their carbon emissions and acquiring carbon offsets, carbon credits, or renewable energy credits (RECs) to offset any remaining carbon emissions.



CWP does not consider its power contract with Covanta's municipal waste-to-energy plant renewable or sustainable since it combusts waste to generate electricity, emitting carbon and other harmful emissions to the atmosphere. On the other hand, biomass generation is considered a renewable form of energy, even though it also emits carbon and other emissions. Biomass generation is considered renewable since it is a carbon-neutral fuel that traps carbon from the atmosphere during the growth cycle of biofuels and then releases only the same amount of carbon during the combustion process. In addition, unlike solar PV, biomass generation is generally a "dispatchable" (on-demand) power source available at any time of day.

It is important to note that while a net-zero carbon scenario was analyzed, CWP is primarily focused on roadmaps based upon 100% renewable or carbon-free targets. This is primarily due to net-zero carbon plans using carbon offsets or renewable energy credits to reach the intended goal instead of reaching a sustainability goal oriented around true zero-carbon options (see Appendix B: List of Abbreviations and Acronyms for term definitions).

2.2 Scope of Work

The scope of work for the contracted study primarily involved the following activities:

1. **Data gathering:** Quanta Technology presented CWP with a list of over 25 data items to be analyzed and serve as the basis for many of the inputs used in the subsequent modeling effort. CWP diligently provided the data items, including electric utility organization and staff descriptions, maps and descriptions of transmission interconnections, data on generators or energy storage owned by CWP and power purchase agreements, system consumption data including load profiles, historical energy consumption data peak demand, energy forecasts, photovoltaic (PV) data, electric vehicle (EV) data, home electrification forecasts, and historical and current city carbon levels. This data was sometimes supplemented with relevant industry sources where CWP data was unavailable.
2. **Initiation workshop and strategic discussions:** CWP and Quanta Technology held a one-day workshop comprised of several core sessions with targeted discussion, including background discussion, an overview of Quanta Technology's probabilistic integrated resource planning (IRP) process, an alignment around metrics and modeled scenarios, a review and preliminary analysis of supplied data, and several discussions on assumptions and next steps.
3. **Modeling plausible scenarios to reach zero emissions:** Utilizing the provided data items along with the information learned from the initiation workshop, Quanta Technology commenced an effort to customize its IRP process using the supplied data and learned information and used its proprietary capacity expansion program known as probabilistic integrated resource planning (pIRP).

The three agreed scenarios (100% renewable 2050, 100% net-zero carbon 2050, and 80% renewable 2035) were analyzed. They were augmented by capturing a total of 15 different scenarios representing variations in key scenario elements such as adoption rates, load forecasts, pricing variations, and cost of capital/debt. These results better assist CWP in selecting the best path, targets, and portfolio mix to reduce the carbon emissions from their electricity consumption. Ultimately, CWP will need to balance the achievement of targets against affordability, available generation options in Florida, and CWP's comfort level in adopting new generation technologies (e.g., biofuels and green hydrogen).



4. **Results compilation:** Quanta Technology worked collaboratively with the CWP to review draft results and align on assumptions and material to be presented. Additional questions for key stakeholders were also considered and addressed as part of the presentation of the final results. Results are captured in this report and summarized in an executive stakeholder presentation.
5. **Stakeholder presentations:** The executive stakeholder presentation was delivered to a joint session of the Utilities Advisory Board and the Keep Winter Park Beautiful and Sustainable Advisory Board, as well as a separate presentation for the City Commission.



3 PROBABILISTIC IRP MODELING OVERVIEW

3.1 Philosophy and Approach

The robust response from regulators, utilities, and corporations to climate change in recent years has culminated in many declaring their commitments to carbon reduction goals reaching 100% between 2035–2050.

Traditional IRP processes and tools have served the industry well over the past 30 years. However, they are increasingly challenged due to the following:

- Increased uncertainties in load development, electrification, technology, and grid development.
- Reliability concerns are not modeled due to the high penetration of inverter-based resources (IBRs including batteries, solar, and wind).
- The dependence of resource development on the availability of transmission and distribution (T&D) hosting capacities is not co-optimized.
- Resilience requirements associated with intermittent weather-dependent resources and grid vulnerabilities are not modeled.
- Energy storage capacity (i.e., duration) is pre-selected and not optimized.
- Energy storage value is often restricted to energy balancing, while the full benefits stack is not exploited.

Quanta Technology, LLC, and Sandia National Laboratories embarked on a multi-year effort to create a probabilistic IRP (pIRP) software tool to address these challenges and ensure robust pathways to reaching 100% carbon reduction goals while preserving system reliability and resilience.

pIRP is a significant enhancement to traditional IRP tools to assist utilities in evaluating and selecting decision pathways that are flexible and adaptable in the face of increasing uncertainty and changes in technology, policy, consumption patterns, and business models. The traditional scenario planning and sensitivity analysis approaches are augmented with probabilistic analysis and real option valuation methods to balance the costs and risks properly.

The drive to high renewable futures based on intermittent technologies such as solar PV and wind will necessarily drive the need for flexible companion assets such as battery energy storage and demand response (DR), long-duration storage options, and renewable fuel-based solutions. pIRP optimizes the capacity buildout to reduce the overall cost to ratepayers while achieving renewable goals and maintaining system reliability.

Figure 1 shows the complete process of capacity planning, starting with defining policy drivers and resource strategies to derive a set of study scenarios. Policy drivers can include carbon reduction goals, electrification adoption rates, and affordability targets, among other factors. Resource strategy includes the practical aspects of resource development options, such as focusing on self-sufficiency or reliance on imports and a preference toward centralized versus microgrids and distributed resources. The set of scenarios bound the range of various factors that are important to decision-makers.



In addition to defining discrete scenarios, pIRP allows the development of probabilistic uncertainty models of key drivers and factors for more complete characterizations of risks and uncertainties, including resource capacities, cost impacts, and carbon reduction levels.

The output of the pIRP is a set of metrics and resource plans. These can be calculated for each discrete scenario or summarized across the range of probabilistic samples.




Figure 1. pIRP Process Overview

3.2 pIRP Model Overview

The following are the key modeling features of pIRP:

- The power system is modeled spatially and temporally. pIRP uses a zonal representation for system resources and models distribution hosting capacities, transmission deliverability capability within each zone, and energy transfer capability between zones. The ability to expand these grid capabilities and the associated costs are also modeled. pIRP utilizes time buckets to represent periods of time within a day. The duration of time buckets is flexible, but the finer the resolution, the longer the simulations will require.




Figure 2. Zonal Representation of the Power System




Figure 3. Time Buckets Representation of Time

- The load forecast of each zone can be specified by providing peak and hourly profiles of multiple load components such as residential, commercial, streetlight, EV charging, and storage charge-discharge profiles. The tool provides flexibility in defining load components.
- Users can define many resource types, such as solar PV, nuclear, and renewable energy credits (RECs). Each resource type has many attributes that differentiate it from other resources, such as its capacity credit or effective load carrying capability (ELCC), asset life, ability to store energy, and duration of storage.
- Fuels can be specified regarding their cost projections, carbon content, and whether they are renewable.
- The user specifies existing resources and acceptable types of future resources in each zone. Each resource will have many attributes such as its connectivity to transmission or distribution system, heat



rate, outage rates, per unit capital and operational costs, fuel selection, capacity buildout capability annually, and in total, 8760 production profiles, if applicable, maximum operational hours in a year, minimum generation levels, ramp rates, etc.

- T&D hosting capacities and tie-line power transfer capabilities. The maximum expansion capability and per-unit costs can be specified.
- Uncertainty can be modeled using statistical functions and associated parameters. Data inputs (such as peak load, load growth rates, fuel cost, ELCC, etc.) can be treated as uncertain.
- Resilience against renewable drought can be specified, such as lack of solar or wind resource production over several consecutive days. This resilience aspect, including energy supply during and after storm events, was out of scope for this study. Average weather was assumed in the development of resource portfolios.
- pIRP imposes several constraints, including energy balance for each zone at the time bucket, capacity requirements in each zone, including reserve margins, ramping requirements to ensure frequency stability, variable resource penetration limits, and resilience targets.
- pIRP formulates the capacity expansion as a linear program (LP) and runs a Monte Carlo using Latin hypercube sampling to generate probable outcomes.
- The user specifies for each zone the renewable targets over time.
- The user selects the duration of the optimizations (1–30 years).
- pIRP co-optimizes resource capacity buildout (including retirements), resource dispatch and curtailments, and T&D grid expansion to achieve minimal cost to ratepayers while achieving renewable targets and reliability constraints. Figure 4 summarizes the various components of pIRP.




Figure 4. pIRP Modeling Capability

- The output of pIRP can be summarized physically and financially for each zone and each year (sample output is shown in Figure 5, Figure 6¹, and Figure 7).

¹ Technologies referenced in Figure 6 and elsewhere in the report are defined in Table 16 in Appendix B: List of Abbreviations and Acronyms.




Figure 5. pIRP Sample Output 1




Figure 6. pIRP Sample Output 2




Figure 7. pIRP Sample Output 3



4 FORECASTS AND OTHER DATA INPUTS

4.1 Overview

Any long-range analysis of supply resource options requires much data, including historical data, current and future energy resource characteristics, and forecasts regarding future conditions and costs. The data requirements required for this study can be generally categorized into the following topics:

1. Load forecast
2. Distributed solar and storage
3. EV growth
4. Renewables and battery storage costs
5. Energy efficiency (EE) and DR forecast
6. Natural gas fuel price forecast
7. Renewable energy credit (REC) Pricing
8. Financial assumptions

Quanta Technology worked with CWP to develop a set of historical data and then determine forecasting methods and assumptions that would provide the needed input data to the terminal year of the study (2050). These forecasted data and assumptions provide the foundation of the technical analysis used to select the preferred resource portfolios that could meet CWP renewable targets at the lowest costs. Since developing a single accurate forecast for the next 27 years is nearly impossible, planners typically develop multiple forecasts of conditions intended to provide a likely range of future outcomes for most of the needed assumptions.

The following subsections summarize the data sources and methods used to create forecasts for each planning element.

4.2 Gross Customer Usage

To estimate the type and cost of energy resources needed by CWP to achieve its 2050 renewable targets, the analysis must first start with a forecast of the energy and peak demand of CWP customers. CWP was able to provide Quanta Technology with ten years of historical data. The most recent ten years of CWP annual energy are shown in Figure 8.




Figure 8. Historical Annual CWP Energy Consumption and System Peak Demand

The average annual energy use growth rate for these last ten years has been 0.09%. This was virtually zero growth in sales when much of this time included a generally robust economy and real estate market. Each of the last six years (2017–2022) has recorded lower annual sales than the previous three years (2014–2016). While a six-year downward trend is significant, the time period included multiple years of impacts from the COVID-19 pandemic and may not predict future energy consumption.

provides the historical annual load factor for CWP for the last ten years, which has been remarkably consistent, indicating that there has been very little change in the demand served by CWP.




Figure 9. CWP Annual System Load Factor

CWP did not have a recent, long-range energy and demand forecast that could be used for this analysis. Developing a long-range forecast of CWP energy and demand using typical methods² was beyond the scope of this analysis. Even with excellent data and a rigorous methodology, forecasting is an inexact science. Since this analysis aimed to assess the feasibility of CWP achieving its 100% renewable targets, creating a precise CWP forecast was less important to the results than analyzing results across a range of forecasts that would serve to bracket the CWP energy forecast. Since central Florida is served by multiple utilities, Quanta Technology and CWP staff decided that the load growth projections of other nearby Florida utilities could serve as potential, reasonable proxies for the CWP's expected growth.

The Florida Public Service Commission (PSC) requires that each of the large utilities in Florida file a ten-year site plan (TYSP) in April of each year, which includes information on the utilities in the state. Among the data in these filings is an annual forecast of its energy requirement for the next ten years. Quanta Technology reviewed the individual 2022 TYSP filings of the utilities and the summary of all the files prepared by PSC: Review of the 2022 TYSP of Florida's Electric Utilities³. From the reporting utilities, Quanta Technology selected four utilities that were believed to provide useful input to estimate the future CWP growth rate: OUC, FMPA, Florida Power and Light (FPL), and Tampa Electric Company (TECO). The ten-year energy forecasts for each of these utilities were normalized to their respective 2022 sales and then charted in Figure 10.

² Typical energy forecasts for long range utility resource planning are based on weather normalized data and end-use or class-differentiated, econometric, multivariable regression.

³ FL PSC Review of the 2022 Ten-Year Site Plans of Florida's Electric Utilities, October 2022.




Figure 10. Forecast of Florida Utility Growth Rates

As can be seen in Figure 10, the average annual growth rates vary from a high of 1.74% for OUC to a low of 0.55% for TECO. OUC, FMPA, and FPL have a similar growth trajectory in the first four years (2022–2026) until OUC diverges with a significantly higher growth rate in the last five years (2027–2031) than the other two utilities.

CWP is already densely developed with limited opportunity for future growth from new customers or developing vacant land. Its historic growth over the last nine years has been virtually flat, averaging only 0.09% yearly. CWP's future growth will be driven by the expanded energy use from its existing customers through increasing the energy density of existing customers, such as by expanding floor space and end uses on existing residential and commercial lots.

After reviewing the growth projections in the 2022 TYSP of the nearby utilities, Quanta Technology selected an expected CWP energy growth rate consistent with CWP's average annual growth rate over the last ten years, or 0.09%. This average reflects a continuation of virtually flat load growth for the embedded end users and customers. This expected load growth does not explicitly consider the potential impacts of end-use electrification (e.g., changing gas space and water heating to electric appliances). However, as discussed later in this report, Quanta Technology has addressed the forecasted impacts from increased distributed generation (principally distributed solar), distributed batteries, and EV charging separately as energy and load modifiers to the embedded system energy and peak demand.

Quanta Technology selected the annual average of the projected FMPA and FPL energy growth, or 1.15%, as the value of the high- or upper-end load forecast for this CWP study. While still low, this 1.15% represents a significant annual growth for embedded load, particularly when the growth rate does not include the expected impacts from EV charging. Quanta Technology believes the 1.15% annual growth should be on the upper end of growth rates that CWP could expect. This upper-end growth was selected for CWP since a higher growth rate was thought to make achieving the target renewable generation more



difficult. Figure 11 below shows the expected and high energy forecast for CWP, and Figure 12 provides a forecast of the CWP system's peak demand.




Figure 11. CWP Forecasted Annual Energy Consumption




Figure 12. CWP Forecasted System Peak Demand

The energy and demand forecasts in the prior charts are forecast prior to any adjustment for the impacts of EE, DR, and electric vehicles (EV). Future loads are expected to vary from the values in Figure 11 and Figure 12 due to increases in EV charging loads and reductions due to energy efficiency programs that CWP plans to implement for both customer and city-owned facilities.



4.3 Distributed Solar and Storage

Distributed solar and storage are highly dependent on various industry forces, including technology advancements in EVs, storage, and PVs, as well as consumer adoption. The technology model for distributed solar and storage is considered mature technology that assumes:

- EV chargers will incrementally improve
- PV modules will incrementally improve
- Battery storage is commercially available for households and modeled after the size of a Tesla Powerwall

CWP and its residents have some influence on distributed solar and storage adoption rates, and these rates have further been segmented into different categories:

- Residential single-family homes
- Multifamily homes
- Commercial buildings
- CWP assets
 - Commercial buildings
 - Industrial areas

Appendix D: NREL PVWatts Solar Production Estimate shows the NREL PV power estimate for a 1000 sq ft roof, which was used on a unit basis to provide estimates for solar production. Multiple residential single-family homes (SFH) adoption assumptions for solar, storage, and EV were created for this study. Solar rooftop installations in Florida expanded due to state tax credits. Without tax credits, adoption slowed drastically. We do not assume tax credits will be the sole driver of adoption, but they will certainly be one of the key drivers. Early EV adopters have also been shown to be closely aligned with those SFH that have installed solar PV. Our model assumes growth across a mix of three types of SFHs with rooftop solar PV, batteries, and EV chargers:

1. An SFH with 500 sq ft of solar PV panels, a Tesla Powerwall battery, and an EV charger that draws, on average, 24 kWh per day.
2. An SFH with 743 sq ft of solar PV panels and a Tesla Powerwall battery that has a net-zero energy draw per day. A net-zero energy installation has sufficient solar PV energy production capacity to offset 100% of the location's annual energy consumption. No EV is included in this SFH variation.
3. An SFH with 928 sq ft of solar PV panels, a Tesla Powerwall battery, and an EV charger that has a net-zero energy draw per day.

Forecasts for the residential solar PV and batteries are provided in Appendix E: Residential Rooftop Solar and Battery Forecasts and Appendix F: Forecast of Rooftop and Ground Mount Solar PV on CWP-Owned Property. The residential batteries in these installations are assumed to be controlled by the homeowner.

Multifamily homes and commercial buildings are considered net consumers of energy. Forecasting solar PV and EV charger installations on landlord-owned multifamily homes is complex principally because they are site-specific and landlord-specific. It is likely that solar PV and EV chargers on landlord-owned, multifamily homes will significantly lag the installations for SFHs and have only a small impact on CWP



loads within the next 5–10 years. For these reasons, Quanta Technology did not include a separate forecast for the multifamily homes.

For CWP-owned assets, the adoption rate of solar on these commercial buildings was based on the year of expected roof replacements. For buildings that did not have an estimated year of roof replacement, the expected solar kW's were evenly distributed until 2050. Industrial areas such as the CWP lift stations were included in this analysis.

In addition, Quanta Technology developed an estimate of the EV charging that will be performed by business commuters who work within the CWP and charge their vehicles at work during the day.

For each of the elements discussed in this section, an expected forecast was created, as well as a high and low forecast. These three forecasts of the contributions from the distributed solar, storage, and EV charges were then added to the different scenarios as noted in Table 8 and Table 9.

This study did not consider or include any potential electric grid upgrades that may be needed to enable the expected large influx of distributed solar and EV charges. Evaluating the grid requirements as residents install more distributed solar and EV chargers will be part of future studies.

4.4 Electric Vehicles

Like the development of the CWP energy forecasts for this study, Quanta Technology looked to the forecasts of other Florida Utilities and their 2022 TYSP to develop a forecast of CWP EV charging loads. Table 1 summarizes the expected growth in the number of EVs in each of the utilities noted⁴.

Table 1. 2022 TYSP: Estimated Number of EVs

Year	FPL	DEF	TECO	JEA	GRU	TAL	Total
2022	116,202	33,325	12,218	4,220	1,065	1,158	168,722
2023	162,141	42,404	14,890	5,477	1,331	1,469	227,712
2024	220,697	52,918	17,742	6,939	1,664	1,832	301,792
2025	293,809	65,134	20,785	8,589	2,080	2,253	392,650
2026	391,240	79,267	24,119	10,419	2,600	2,736	510,381
2027	512,104	95,455	27,808	12,441	3,250	3,288	654,346
2028	657,776	114,021	31,977	14,689	4,063	3,921	826,447
2029	831,693	135,439	36,561	17,187	5,078	4,640	1,030,598
2030	1,037,328	160,059	41,599	19,951	6,348	5,459	1,270,744
2031	1,273,609	188,139	47,156	22,993	7,935	6,378	1,546,210

⁴ FL PSC Review of the 2022 Ten-Year Site Plans of Florida's Electric Utilities, October 2022, Table 2.



Table 2 summarizes the expected annual energy consumption for cumulative EV charging in each utility noted.⁵

Table 2. 2022 TYSP: Estimates EV Annual Charging Consumption (GWh)

Year	FPL	DEF	TECO	JEA	GRU	TAL	Total
2022	231	24	35	17	4	4	314
2023	401	54	46	24	5	5	534
2024	623	92	57	32	6	6	816
2025	908	139	70	41	8	7	1,173
2026	1,289	199	-	51	9	8	1,642
2027	1,771	275	101	62	12	10	2,231
2028	2,361	367	118	75	15	12	2,948
2029	3,075	470	138	89	18	14	3,804
2030	3,930	586	160	104	23	17	4,819
2031	4,913	712	183	121	29	20	5,977

Table 3 summarizes the expected annual energy consumption per vehicle for charging EVs in each utility noted. The per-vehicle energy consumption in Table 3 is derived by dividing the annual charging energy for all EVs shown in Table 2 by the annual number of EVs in Table 1.

Table 3. Annual Energy Consumption Per EV (kWh)

Year	FPL	DEF	TECO	JEA	GRU	TAL	Average
2022	1,988	720	2,832	4,076	3,568	3,022	1,862
2023	2,473	1,276	3,056	4,400	3,606	3,063	2,345
2024	2,823	1,737	3,230	4,626	3,606	3,057	2,704
2025	3,090	2,133	3,382	4,797	3,606	3,063	2,987
2026	3,295	2,511	-	4,914	3,615	3,070	3,216
2027	3,458	2,876	3,625	5,008	3,600	3,072	3,409
2028	3,589	3,217	3,700	5,085	3,593	3,086	3,567
2029	3,697	3,473	3,772	5,149	3,604	3,103	3,691
2030	3,789	3,662	3,834	5,198	3,607	3,114	3,792
2031	3,858	3,785	3,881	5,241	3,604	3,120	3,866

⁵ FL PSC Review of the 2022 Ten-Year Site Plans of Florida's Electric Utilities, October 2022, Figure 15.



Quanta Technology used the FPL data in the tables above, together with FPL service territory population and FL State vehicle registration data, to estimate the percent registered vehicles in FPL's service territory expected to be EVs for the next ten years.




Figure 13. Resident and Commuter Annual EV-LDV Charging Energy: Expected Scenario




Figure 14. Annual Resident and Commuter EV-LDV Charging Energy



As seen in Figure 14, the high and expected forecasts each reach a maximum EV penetration, estimated to be 95% of registered light-duty vehicles (LDVs). The high forecast reached this maximum in 2040, and the expected forecast reached this maximum in 2045. The low forecast is still growing in the final year of the forecast and will reach a maximum of 90% penetration in the year 2050. Since EVs and their charging load are a new addition to utility planning, much uncertainty is associated with forecasting how rapidly the charging load will grow. Assessing higher growth rates of EVs that, in turn, have higher charging impacts is prudent in a feasibility analysis such as this study. In assessing new loads, it is better to be conservatively high rather than too low when assessing the costs of serving customer loads with a new set of resources. The forecasts of the LDV EVs for CWP residents are provided in Appendix G.

Adoption of residential electric vehicles, solar panels, and energy storage/batteries are assumed to be closely aligned and increasingly adopted as roofs and vehicles are replaced. The study expects a reduction in net energy supplied to residents. The study does NOT assume significant buyback of solar power under net metering. It does not include any potential “Virtual Power Plant” benefits, although both may occur if “Time of Use” rates are implemented as recommended. The study projects that residents will invest in electric vehicles, rooftop solar, and batteries voluntarily at personal cost with the following forecasts by 2042:

- Up to 95% of the registered vehicles in CWP may be electric vehicles.
- Approximately 35% of residential rooftops will have solar PV installed, with the capacity to generate approximately 49,000 MWh of energy per year, which is approximately 11% of the total CWP requirement.
- Approximately 35% of residences will have battery energy storage systems (BESS) installed.

4.5 Generation Technologies and Battery Storage

Quanta Technology used PPA pricing from existing CWP contracts and other data available for Florida power costs to estimate that future purchases from the Florida grid would. Florida currently relies principally on fossil-fueled resources. However, as FPL and other utilities evolve their system to cleaner resources, the power costs from the Florida grid are estimated to escalate at 2% annually, regardless of the CWP decisions for its power supply. Quanta Technology also assumed that the purchased power market in Florida would continue to provide CWP options to purchase specific types of power from large suppliers, such as FPL, OUC, and the FMPPA.

Quanta Technology used the technical characteristics for optional new resources that could be constructed in the future to fulfill the needs of CWP and other Florida utilities. It cost data from the National Renewable Energy Laboratory (NREL) Annual Technology Baseline (ATB) and a 2022 NREL Solar and Energy Storage Cost Benchmarks Analysis⁶ (collectively referred to as NREL data). While FMPPA will be the source of some early solar PV contracts, it may not be the provider for future contracts. The source of our future cost estimates is based on NREL and DOE data. The NREL data provides an extensive database on renewable, fossil, and energy storage technologies that are regularly used as a basis for future costs in utility resource planning. The NREL data also provides projected costs of technologies, for example, the decreases expected in solar PV and battery costs from greater manufacturing volume and other

⁶ Ramasamy, Vignesh, Jarett Zuboy, Eric O’Shaughnessy, David Feldman, Jal Desai, Michael Woodhouse, Paul Basore, and Robert Margolis. 2022. U.S. Solar Photovoltaic System and Energy Storage Cost Benchmarks, With Minimum Sustainable Price Analysis: Q1 2022. Golden, CO: National Renewable Energy Laboratory. NREL/TP-7A40-83586. www.nrel.gov/docs/fy22osti/83586.pdf.



technology advances. Table 4 provides a summary of the costs for the set of technologies that were considered in the resource plan for CWP.

Table 4. Generation and Storage Technologies Costs

Technology	Installed Cost \$/kW (REC in \$/MWh)	Cost Year	Annual Cost Escalation	Cost Stabilization Year	Fixed O&M (\$/KW- yr)	Variable O&M (\$/MWh)
Combustion Turbine (CT)	\$1,000	2021	2%	10	15.00	2.00
Internal Combustion Engine (CE)	\$650	2021	2%	5	30.00	10.00
Green Hydrogen-Fueled CT (CT-Hydrogen)	\$1,500	2021	2%	10	20.00	4.00
City Owned Distributed Solar, Rooftop (Dsolar-CommRoof)	\$2,208	2021	-2%	10	18.10	0.00
City Owned Distributed Solar, Ground-mount (Dsolar-CommGround)	\$2,328	2021	-2%	10	17.20	0.00
Utility Scale Solar PV (USolar)	\$1,386	2021	-2%	10	16.10	0.00
Battery Energy Storage System (BESS)–1 hr. (ESS-1)	\$710	2021	-2%	5	15.00	0.00
BESS–2 hr. (ESS-2)	\$1,070	2021	-2%	5	14.00	0.00
BESS–4 hr. (ESS-4)	\$1,790	2021	-2%	5	12.00	0.00
BESS–10 hr. (ESS-10)	\$3,950	2021	-2%	5	10.00	0.00
Biofuel Internal Combustion Reciprocating Engine(Biomass)	\$500	2021	2%	5	10.00	0.00
Demand Response (DR)	\$50	2021	2%	5	10.00	0.00
Energy Efficiency (EE)	\$20	2021	2%	5	10.00	0.00
Renewable Energy Credit (REC)	\$2.5	2021	2%	10	0.00	0.00

The general industry consensus is that the forecasted installed cost for solar and battery storage technologies will continue to decline in cost for the foreseeable future through continued manufacturing and solar PV performance improvements. In addition, legacy technologies such as combustion turbines are expected to continue to increase in cost based on inflationary pressures. The NREL ATB projects cost declines in renewable technologies and battery storage and cost increases in legacy technologies through 2050. Supply disruptions and changing tariff structures resulted in an increase in solar PV costs in 2021 and 2022. These recent cost increases are expected to be temporary as the solar PV manufacturers adjust in response to the changing world market.



To remain conservative in the cost projections of future technology costs used in this study, Quanta Technology estimated a lower near-term price decline for solar PV and batteries than the NREL ATB estimate. In addition, Quanta Technology estimated the price declines would stabilize after ten years for solar PV and after five years for battery storage. Further price increases for the legacy generation technologies also had a similar end to their forecasted continuing escalation where their costs would stabilize. The combination of these adjustments to the future escalation of technology costs provides a conservatively high cost for solar PV and battery storage and a conservatively low cost for legacy technologies.

The graph shown in Figure 15 presents the annual costs of the subset of technologies that were ultimately included in the supply portfolios described later in this report.




Figure 15. Projections of Generation and Storage Technologies Installed Costs

Table 5 summarizes the projected solar PV costs.



Table 5. Solar PV Costs for Key Milestone Years (Installed Cost—\$/kW)

Solar PV Technology	2023	2035	2042	2050
Residential Rooftop Solar	\$3,400	\$2,892	\$2,892	\$2,892
Commercial Solar PV, Rooftop (Dsolar-CommRoof)	\$2,121	\$1,804	\$1,804	\$1,804
Commercial Solar PV, Ground-mount (Dsolar-CommGround)	\$2,236	\$1,902	\$1,902	\$1,902
Utility Scale Solar PV (USolar)	\$1,331	\$1,253	\$1,253	\$1,253

Table 6 summarizes the costs for battery storage installations.

Table 6. Battery Storage Costs for Key Milestone Years (Installed Cost—\$/kWh)

Battery Energy Storage Technology	2023	2035	2042	2050
Residential BESS—2.5 hr	\$1,443	\$1,359	\$1,359	\$1,359
Commercial BESS—4 hr	\$774	\$729	\$729	\$729
Utility Scale BESS—4 hr (ESS-4)	\$514	\$484	\$484	\$484

Quanta Technology did not consider some of the technologies listed in the NREL data since they were inappropriate for CWP and Florida (e.g., hydroelectric, pumped storage, and distributed wind technologies). The CAPEX costs shown in Table 4 include assumed interconnections costs but do not include any grid upgrades. The costs of solar PV and utility-scale battery storage technologies are assumed to decline by 2% annually (based on the Annual Cost Escalation data) until 2026 (based on the Cost Stabilization Year data) and remain flat afterward. In 2021, a utility-scale solar PV cost was assumed to be \$1,386/kWac (assuming a DC-to-AC ratio of 1.2).

The cost of natural gas is assumed to be \$3.00/MMBTU in 2019, and it is expected to increase at a 2% escalation per annum.

The utility and transportation industries are planning to use an increasing quantity of batteries in their efforts to reduce carbon emissions. Mining minerals, manufacturing, and disposing of these increasing quantities of batteries bring environmental issues to a scale new to the world economy. At the request of CWP, Quanta Technology has prepared a summary of the lifecycle considerations of batteries in Appendix C: Battery Lifecycle Considerations.

4.6 Energy Efficiency and Demand Response

According to the United States Department of Energy, EE and DR can be described as:

Energy efficiency is the use of less energy to perform the same task or produce the same result. Energy-efficient homes and buildings use less energy to heat, cool, and run appliances and electronics, and energy-efficient manufacturing facilities use less energy to produce goods.



Energy efficiency is one of the easiest and most cost-effective ways to combat climate change, reduce energy costs for consumers, and improve the competitiveness of U.S. businesses. Energy efficiency is also a vital component in achieving net-zero emissions of carbon dioxide through decarbonization.⁷

Demand response provides an opportunity for consumers to play a significant role in the operation of the electric grid by reducing or shifting their electricity usage during peak periods in response to time-based rates or other forms of financial incentives.⁸

Quanta Technology's experience with other utilities confirms this statement. Most utilities find that numerous EE measures, such as programs that incentivize the shift to higher efficiency appliances and building envelopes⁹, are much less expensive than purchasing or generating the electricity saved by these programs. In essence, many EE measures cost the utility less to manage the EE program and pay incentives than to generate or buy the energy. It is widely accepted that any program to reduce the environmental impacts of electric energy supply should include a robust energy efficiency program that first attempts to reduce the energy required cost-effectively.

DR programs are focused on reducing a utility's peak demand on a daily or seasonal basis. The value of the system peak demand dictates the generation and storage capacity that must be built or purchased and the capacity of the transmission and distribution system needed to deliver the energy. Reducing the system peak demand can reduce, delay, or eliminate costs through the utility system. DR programs use various measures to reduce or eliminate the demand for electrical end uses during peak demand. With the introduction of distributed solar and batteries in homes and businesses, DR programs can be designed to incentivize customers to use a portion of their battery's stored energy when the most energy is needed. Like the EE programs, Quanta Technology recommends that CWP implement a comprehensive DR program for city facilities and residential and commercial customers to minimize CWP's future generation, transmission, and distribution capacity needs.

Quanta Technology had limited data on CWP's forecasted plans and projected impacts of energy efficiency programs for the CWP system. However, since these energy efficiency programs can generally offer the lowest cost "energy resource" available to utilities, Quanta Technology estimated the impacts that the future energy efficiency programs implemented by CWP, together with the energy efficiency improvements implemented by CWP customers on their own, will be approximately 2% of the total CWP energy requirement in the early years of the study and grow to approximately 10% in 5 years and remain approximately constant for the remainder of the study¹⁰. The DR was estimated to be constant at 5 MW for the study period. A total DR of 5 MW was considered easily achievable in a program that includes customer and city-owned facilities. These high-level estimates were deemed reasonable because CWP does not have an existing EE and DR program in place for its retail customers.

⁷ U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, <https://www.energy.gov/eere/energy-efficiency>.

⁸ U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, <https://www.energy.gov/oe/demand-response>.

⁹ Examples of EE measures include light-emitting diode (LED) lighting, heat pumps to replace air conditioners and resistance heating, increased attic and wall insulation, window and doors with better insulation values and air seals.

¹⁰ The EE estimate does not address growth of individual end-use energy efficiency improvements. It should be noted that while EE programs do result in lost utility revenue due to the reduction in MWh sold, these programs are also accompanied by a reduction in energy supply costs. In addition, all DR and EE measures should be selected based on the ability to implement and manage them with a positive benefit to cost ratio.



4.7 Fuel Price

Each Florida utility filing a TYSP also files a fuel price forecast for the fuel used in their plans. The PSC has compiled and averaged the fuel price forecasts in the plan reviews. Figure 16 summarizes the filing utilities' average historical and forecasted fuel prices. Quanta Technology chose to extrapolate the average fuel forecasts shown in the TYSPs for use in the CWP study.




Figure 16. TYSP Utilities: Average Fuel Price of Reporting Electric Utilities

However, the TYSP are filed in April of each year. The 2022 TYSP apparently used historical natural gas prices that did not reflect the full impact of the significant increase in natural gas prices in 2022, reaching the highest prices seen since 2008. Figure 17 provide the ten year history the Henry Hub Spot. Henry Hub is a location in Erath, Louisiana, that is a junction point for a number of natural gas transmission lines. The price of natural gas delivered to Henry Hub is used a pricing reference point for the fuel industry.




Figure 17. Ten Year History of Natural Gas Henry Hub Spot Price

Since the price spike in 2022, revised natural gas price forecasts are generally projected to return to lower prices and then begin a slow price escalation as the Energy Information Administration (EIA) natural gas price forecast shows in Figure 18. The actual prices shown in Figure 17 have actually dropped faster than the most recent EIA forecast in Figure 18.




Figure 18. Natural Gas Price Forecast at Henry Hub

Quanta Technology selected three natural gas price forecasts for modeling in the different scenarios:

- **Base** – this forecast started with CWP’s most recent fuel costs in late 2022, which reflected the 2022 steep price increase in natural gas prices, and then escalated the price based on available public forecasts. Public forecasts available at the time did not reflect, the 2022 price increase, but only a slow increase in price.
- **Low** – this forecast projected an immediate drop in natural gas fuel prices to recent pre-2022 levels followed by a slow escalation in price consistent with public long term forecasts.



- **High** - this forecast started with CWP's most recent fuel costs in late 2022 and then escalated at a higher annual increase that was reflected in most public forecasts.

Recent natural gas pricing, since the IRP modeling was completed, have been more in-line with the Low natural gas forecast.

4.8 Renewable Energy Credits

One of CWP's three primary renewable targets was achieving a 100% net-zero carbon energy supply by 2050. Net zero implies that some carbon may be released into the atmosphere during electricity generation. However, any carbon released will be counterbalanced by acquiring carbon offsets, carbon credits, or RECs to offset carbon emissions from the energy supply portfolio. The ownership of RECs and carbon credits has become an accepted method to prove to regulators, constituents, or stockholders that an entity has caused the specified renewable energy production or reduction in carbon emissions. Utilities use RECs and carbon credits to prove compliance with legislated renewable portfolio standards (RPS) or the carbon content of their energy supply targets. Cities and corporations use them to demonstrate to constituents and shareholders that they have reduced their carbon footprint by X% or use Y% renewable generation to supply their operations.

Neither the state of Florida nor the Federal government has established any state mandate for carbon emission limitations or RPS for Florida's utilities. While several cities and utilities in Florida have adopted renewable or carbon emission goals, the goals are considered voluntary. The markets for RECs were originally driven by utilities and other entities with a legislative requirement to meet renewable or carbon targets. However, private corporations and cities quickly adopted the use of RECs and carbon credits, similar to CWP, to document their progress toward achieving their voluntary renewable or carbon goals.

The markets have created different types of RECs with different pricing to meet the different needs of their buyers. LevelTen Energy, a player in the REC market, offers the following concise explanation:

"RECs are priced differently depending on whether they are compliant or voluntary market RECs. Compliance market RECs are used to meet renewable portfolio standards (RPS), must meet certain criteria in the RPS statutes, and are often more expensive. Voluntary REC markets are almost exclusively driven by climate-related sustainability goals, making them more common for corporate clean energy purchasers. Since there are fewer strings attached, voluntary market RECs have lower prices. Some states have a tier system for RECs to indicate their positive environmental impact. For example, Tier 1 RECs come from new wind and solar projects. The RECs with a higher carbon-reduction impact are typically more expensive than RECs with a lower impact, like those produced in an already clean grid."¹¹

As noted above, due to the lack of need to meet different state-level requirements for RPS compliance in a specific state, voluntary RECs tend to be much less expensive than compliance RECs. In addition,

¹¹ Introduction to Renewable Energy Certificates (RECs), RTI Essentials and Best Practices, May 14, 2020, LevelTen Energy, Ben Serrurier.



voluntary market RECS are more locationally fungible in that voluntary RECs created in one state can fulfill voluntary renewable targets in any state.

With the current lack of a Florida RPS, Quanta Technology would recommend that any future REC purchases made by CWP to meet environmental targets should be made from the lowest-priced RECs available, which would be expected to be the voluntary market. Quanta Technology has reviewed various voluntary market historical and current pricing to define a REC pricing projection for this study. The forecast of the voluntary REC pricing for this study was based on forecasts of solar and wind RECs at a national level for the years 2023–2042. Linear regression was then used to extrapolate this data for an additional eight years to 2050. Figure 19 illustrates the input forecast and the extrapolated REC prices. The average price was used as the expected REC price for this study¹².




Figure 19. REC Price Forecast

4.9 Financial Assumptions

The primary financial metric to assess optional portfolios of future supply resource options for CWP was the net present value of revenue requirements (PVRR). PVRR is a metric commonly used for public and investor-owned utility decision-making and other industries for analysis that includes multiple years and/or long-lived assets. PVRR is a discounted cash flow analysis that assesses the forecasted cash outlay for capital expenditures, operations, and expenses for each year of the study. For this study, the period of the analysis was 2025–2050. The forecasted annual cash requirements are then discounted based on the cost of capital of CWP. Each year's resulting discounted cash requirements are then summed to arrive at a single value representing the PVRR. This methodology allows different optional supply portfolios to be compared with a single financial metric.

Several financial assumptions are required to perform long-term resource plans and to calculate the PVRR. To assess the possible project financing options available to CWP, Quanta Technology estimated the potential cost of new supply resources being developed and owned by third-party developers and the costs should CWP choose to own new supply resources. The developer's cost of capital determines the cost of new resources for which CWP would contract through a purchase power agreement (PPA). The CWP cost of capital, which represents an estimate of the CWP interest for their future general obligation

¹² REC pricing data compiled from multiple sources.



bonds, is used for estimating the annual costs of CWP ownership of new supply resources and the present value discount factor used for all scenarios.

Table 7. Primary Financial Assumptions

Item	Value
CWP Cost of Capital	3.5%
Developer Cost: Cost of Debt	6.0%
Developer Cost: Cost of Equity	10.0%
Developer Cost: Percentage Debt	50.0%
Developer Cost: Percentage Equity	50.0%
Developer Cost: Cost of Capital	8.0%
Annual Escalation for Capital and O&M Costs	2.0%
Annual Escalation of Purchased Power	2.0%



5 SCENARIO DESCRIPTIONS

5.1 Targets and Scenarios

As noted in early sections, this study was centered around the assessment of three potential targets under consideration for the future CWP energy supply:

- **Target 1:** 100% renewable energy supply by 2050
- **Target 2:** 100% net-zero carbon energy supply by 2050
- **Target 3:** 80% renewable energy supply by 2035 and then 100% by 2050
- **Target 4:** 80% renewable energy supply by 2035, 100% by 2050, with added capacity for storm resiliency

Based on the explicit language in the targets, the study required it to create a forecast and assumption for the year 2050. Since forecasting future conditions (e.g., energy consumption, costs, technology progression, legislative requirements) is such an imprecise science, planners in many industries, including utility resource planners, have adopted scenarios to address the uncertainty of forecasts.

While the scenario is a common term, a definition used in planning is useful for clarity. The following definition is used in this report and commonly understood in planning.

A scenario is a set of future conditions that collectively describe the external environment and conditions within which one is attempting to plan or make a decision. In the case of a resource plan, a scenario description includes a multi-year forecast of external drivers or assumptions important to the analysis. Examples of elements typically included in resource planning scenario descriptions are customer load forecasts, the projected cost of supply options, the forecasted growth of distributed generation installations, etc. A single planning target or input, such as achieving a 100% renewable supply by 2050, does not constitute a scenario, only a single planning input. A scenario requires many planning inputs.

Since it is so difficult to accurately predict future conditions, rather than just planning for a single set of future conditions, a single scenario, planners often create and use multiple scenarios that collectively describe a range of plausible future conditions. Evaluating how resource options perform across a range of potential future conditions enables assessing the resources' flexibility and ability to adapt to changing conditions.

Quanta Technology used this planning methodology with multiple scenarios to assess different options and combinations of resources to achieve each of the three renewable targets that CWP is considering. These three optional targets were expanded into a total of 15 different scenarios:

- Six focused on achieving Target 1 (100% renewable by 2050)
- Five focused on achieving Target 2 (100% net-zero carbon by 2050)
- Five focused on achieving Target 3 (80% renewable supply by 2035 and then 100% by 2050)



- Two focused on achieving Target 4 (80% renewable energy supply by 2035, 100% by 2050, with additional resources added for storm resiliency)

Each of these scenarios looked at different expected forecasts for the following eight categories of planning elements, which were referenced at the beginning of this section:

1. Load forecast
2. Distributed solar and storage
3. EV growth
4. Renewables and battery storage costs
5. EE and DR forecast
6. Natural gas fuel price forecast
7. REC pricing
8. Financial assumptions

Table 8 summarizes scenarios focused on Targets 1 and 2 developed to assess resource options for the first two renewable targets, 100% renewable by 2050 and net-zero carbon by 2050. Table 9 summarizes the remaining additional scenarios developed to assess resource options for the third renewable target, 80% renewables by 2035 and 100% by 2050.



Table 8. Details for Scenarios Focused on Targets 1 and 2

Scenario Count	1	2	3	4	5	6	7	8	9	10	11
Scenario Element	Target 1: 100% Renewable by 2050						Target 2: Net-Zero Carbon by 2050				
	1A	1B	1C	1D	1E	1F	2A	2B	2C	2D	2E
2050 Renewable Target	100%	100%	100%	100%	100%	100%	---	---	---	---	---
2050 Net-Zero Carbon Target	---	---	---	---	---	---	100%	100%	100%	100%	100%
Renewable Electric Supply by 2035	---	---	---	---	---	---	---	---	---	---	---
Load Forecast	Expected	High	Expected	Expected	Expected	Expected	Expected	High	Expected	Expected	Expected
Natural Gas Fuel Price Forecast	Base	Base	Base	Base	High	Low	Base	Base	Base	High	Low
Distributed Solar and Storage	Expected	High	Low	Expected	Expected	Expected	Expected	High	Low	Expected	Expected
New Solar PV on City Rooftops and Land	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
EV Growth	Expected	High	Low	Expected	Expected	Expected	Expected	High	Low	Expected	Expected
Technology Costs	Expected	Expected	Expected	Expected	Expected	Expected	Expected	Expected	Expected	Expected	Expected
EE and DR Forecast	Expected	Expected	Expected	Expected	Expected	Expected	Expected	Expected	Expected	Expected	Expected
REC Pricing	---	---	---	---	---	---	Expected	Low	High	Expected	Expected
Developer Cost of Capital	8.00%	8.00%	8.00%	-	8.00%	8.00%	8.00%	8.00%	8.00%	8.00%	8.00%
CWP Cost of Capital	---	---	---	3.50%	---	---	---	---	---	---	---
Extra Capacity for Storm Resiliency	No	No	No	No	No	No	No	No	No	No	No

Load forecasts are as follows:

- **Expected:** 0.09%, based on the average of historical CWP growth
- **High:** 1.15%, based on average FMPA and FPL forecasts



Table 9. Details for Scenarios focused on Targets 3 and 4

Scenario Count	12	13	14	15	16	17	18
Scenario Element	Target 3: 80% Renewable by 2035 and 100% by 2050					Target 4: 80% by 2035, 100% by 2050, Capacity for Storm Resiliency	
	3A	3B	3C	3D	3E	4A	4B
2050 Renewable Target	100%	100%	100%	100%	100%	100%	100%
2050 Net-Zero Carbon Target	---	---	---	---	---	---	---
Renewable Electric Supply by 2035	80%	80%	80%	80%	80%	80%	80%
Load Forecast	Expected	Expected	Expected	Expected	Expected	Expected	Expected
Natural Gas Fuel Price Forecast	Base	Base	High	Low	Base	Base	Base
Distributed Solar and Storage	Expected	Expected	Expected	Expected	Expected	Expected	Expected
New Solar PV on City Rooftops and Land	Yes	Yes	Yes	Yes	No	Yes	Yes
EV Growth	Expected	Expected	Expected	Expected	Expected	Expected	Expected
Technology Costs	Expected	Expected	Expected	Expected	Expected	Expected	Expected
EE and DR Forecast	Expected	Expected	Expected	Expected	Expected	Expected	Expected
REC Pricing	---	---	---	---	---	---	---
Developer Cost of Capital	8.00%	-	8.00%	8.00%	8.00%	8.00%	8.00%
CWP Cost of Capital	---	3.50%	---	---	---	---	---
Extra Capacity for Storm Resiliency	No	No	No	No	No	Yes with Batteries	Yes, with old fossil units

16 of the 18 scenarios described above assumed that third-party developers/operators would own the utility-scale supply technologies. The power was then sold to CWP through a PPA. Scenarios 1D and 3B provide the resulting costs if CWP owns all or a portion of the new energy technologies sources acquired.

Purchasing utility-scale solar PV and battery storage from a developer is expected to be higher than CWP owning the facilities due primarily to the cost of capital being higher for the developer. The cost of capital for CWP is the interest it must pay on its municipal bonds (assumed to be 3.5% for this study). Whereas the cost of capital for a developer must pay a typically higher interest on its debt (assumed to be 6% for this study) and pay an even higher return to its equity investors (assumed to be 10% for this study). Table 1 summarizes the assumed capital structure (percentage of debt and equity used to finance a project) for developer-owned projects and their resulting weighted average cost of capital (cost of capital) assumed for this study.



Table 10. Developer Weighted Average Cost of Capital

Component	Financing Structure	Cost	Weighted Contribution
Equity	50%	10%	5%
Debt	50%	6%	3%
Weighted Average Cost of Capital			8%

As discussed in Section 4.3, all but Scenarios 3E assumed that CWP would install commercial-scale solar projects on the roofs of a portion of the buildings owned by CWP and on the ground for a portion of the vacant land owned by the CWP. These projects were assumed to be developer-owned projects for which the power was sold to CWP. However, CWP could choose to invest its own capital to install these distributed assets. Table 11 below provides the cumulative capacity and costs of the solar PV facilities assumed to be constructed on CWP-owned buildings and vacant land.

Table 11. Capacity and Costs of Solar PV on CWP Owned Buildings and Vacant Land

Year	Cumulative City Rooftop PV (MW)	Cumulative City Ground Mount PV (MW)	Cumulative Total MW)	Cumulative Cost (\$M)
2035	0.98	0.98	1.96	\$3.8
2042	0.98	2.95	3.94	\$7.5
2050	0.98	2.95	3.94	\$7.5

As show in Table 5, the costs of commercial-scale solar rooftop and ground mount projects are forecasted to remain higher than the costs of utility scale projects in this study.



6 COST AND FEASIBILITY COMPARISONS

6.1 Target 1: 100% Renewable Energy Supply by 2050

The first of CWP's potential energy supply targets identified 2050 as the date for achieving a 100% renewable energy supply. Developing and constructing a utility-scale solar photovoltaic generation facility takes multiple years. Developers of these plants typically identify co-owners and those seeking a PPA to purchase power from the plant owners as early as the development cycle. Having the future energy output of the facility fully committed to either owners or buyers will lower the risks associated with the project and, in turn, the costs of financing. Based on this typical multi-year cycle for solar facility development, Quanta Technology has assumed it will take a few years for CWP to find favorable PPA contracts or ownership positions for its renewable supply. Figure 20 provides the projected renewable energy percent of the CWP requirement for Target 1 (100% renewable by 2050) and Target 2 (80% renewable by 2035). While Target 2 shows a more rapid rise in the renewable energy contribution, both show a slower growth in the study's early years, reflecting that it will take time for CWP to identify, negotiate, and execute favorable renewable energy supply options.




Figure 20. Comparison of Renewable Energy Results for the Two Renewable-Based Targets




Figure 21 provides a chart showing the detailed technologies selected for the pIRP model as the least cost supply additions for Scenario 1A¹³, the first of the six scenarios defined to assess Target 1.




Figure 21. Capacity Additions for Scenario 1A

Solar and wind energy technologies, the two most common renewable energy sources, are considered variable renewable energy (VRE) sources since the energy production of both goes up and down based on

¹³ Technologies referenced in Figure 21 and elsewhere in the report are defined in Table 12 in Appendix B.



the amount of solar or wind energy available. Whereas fossil resources, such as natural gas-fueled CTs or combined cycle plants, are described as dispatchable energy sources that can change the output of the energy produced based on the changing requirements of the system.

A system cannot operate with 100% VRE technologies. It must have other dispatchable technologies that can adjust to supply power as needed in response to the up and down production of VREs and the changes to customer demands. In this analysis performed for CWP, the dispatchable technologies selected by the pIRP model included biomass-fueled plants, batteries, CT-Hydrogen, nuclear, concentrated solar power, and geothermal, which were all even more expensive than CT-Hydrogen plants (see Section 4.5). While biomass is assumed to be a less expensive dispatchable resource than CT-Hydrogen in this study, Quanta Technology has limited the amount of biomass generation available for the pIRP to choose to supply CWP energy requirements. Quanta Technology believes that limiting the biomass generation available to CWP is a prudent assumption for several reasons, but primarily by the expectation that the proximity and quantity of biofuels in Florida will be limited and in high demand as all utilities seek to reduce the carbon emissions of their energy supply. Limiting the amount of biomass energy available to the pIRP model selects the next higher-cost energy resource once the biomass generation reaches its limit. A table listing the annual capacity purchases by technology for Scenario 1A can be found in Appendix H, Table 20.

Figure 22 illustrates the annual energy cost for Scenario 1A based on three different measures of energy costs. The first measure in the blue line is the actual projected cost of revenue requirements for the energy supply in nominal dollars (inflation included), divided by the total energy consumptions, shown in \$/MWh. Notice the blue line's steep growth in the cost of power beginning in 2045 and the sustained high costs in the final six years of the study (2045–2050). This rise in costs is driven by introducing an extremely high-cost renewable energy technology to meet the needs of CWP. The high-cost technology added, which drives the costs up in the final years, is combustion turbine generators (CT) fueled with green hydrogen (CT-Hydrogen). The pIRP model selected the CT-Hydrogen technology for the final years of the study. This steep cost rise as the supply portfolio approaches 100% clean energy is typical of other 100% renewable and zero-carbon studies. The energy cost of imports and exports between CWP and neighboring utilities is assumed to be \$50/MWh in 2021 and is expected to escalate at 2% annually in nominal terms.

Note that the annualized cost in the blue line and the other cost presentation are all based on nominal dollars. The two alternative cost streams discussed below, the levelized cost of energy (LCOE) and the LCOE with an escalator, are constructed using a present value discounting of the annualized costs to 2021 dollars.




Figure 22. Annualized Cost of Energy and LCOE: Scenario 1A Based on 2023–2050

The dashed horizontal line presents the levelized cost of energy (LCOE) with no annual escalation, \$103/MWh, which is the cost of energy equivalent to the blue line’s actual energy cost if both were stated on a present value (PV) basis. Note that this report’s PV and LCOE values are based on present value discounting to 2021 dollars. The LCOE calculation takes the entire stream of forecasted actual annual costs shown in the blue line and creates an equivalent single constant \$/MWh value. The LCOE calculation flattens the year-to-year variations in actual costs and provides a single \$/MWh to represent the multi-year stream of differing values shown in the actual costs (blue line). In application, the results of the 1A would provide an LCOE that partially pays for the high costs in the final six years by increasing the costs paid in the prior years.

Finally, the orange line shows the LCOE with an annual escalation of 3%. The 3% escalation is not equivalent to inflation. However, the value Quanta Technology selected to convert the LCOE to an equivalent stream of annual costs better matches the increasing trend in production costs. The orange line is equivalent to the dashed gray and blue lines if all three were compared on a PV basis. An LCOE with an escalation is a common method that provides a lower cost than the LCOE without escalation in the early years and a higher cost later. In these 1A results, note that both LCOE methods provide higher than actual costs in the early years, but both also provide lower than the actual cost in the final years of the study, where a steep climb in forecasted actual costs is seen.

As noted earlier, forecasting future conditions becomes more complex and uncertain the further one extends the analysis into the future. Unfortunately, the final six years of the results of Scenario 1A above have a significant impact on the overall results and the LCOE values shown. Changes to the results of the last six years of the study could, in turn, significantly impact overall LCOE results.



To illustrate the impacts of the later years in the study results, Quanta Technology shortened the period of the results assessed to determine the LCOE values from the original period of 2023–2050, or a total of 28 years, to the period from 2023–2042, or a period of 20 years. The same results from the full 28-year analysis were used to perform this analysis, but only the first 20 years of the results were used to calculate the LCOE with and without escalation. The results of assessing only the first 20 years of the result of Scenario 1 are shown in Figure 23.




Figure 23. Annualized Cost of Energy and LCOE: Scenario 1A Based on 2023–2042

The results in the 20-year analysis of Figure 23 show an identical blue line as the first 20 years in Figure 19. However, using the shorter time horizon for the present value calculations produces significantly reduced LCOE values. The LCOE with no escalation of \$103/MWh for the 28-year analysis in Figure 19 Figure 22 drops to \$88/MWh in the 20-year analysis of Figure 23, a 15% reduction in the value. The lower LCOE in the 20-year analysis is driven by eliminating the costs in the final 8 years. Scenario 1A reaches a 71% renewable contribution to the CWP energy supply by 2042.

6.2 Target 2: 100% Net-Zero Carbon by 2050 Target

The chart shown in Figure 24 summarizes the technologies and capacities selected by the pIRP model for Scenario 2A, which focuses on achieving 100% net-zero carbon by 2050. While much of the technologies and capacities selection is similar to Scenario 1A, the notable difference is the fact that the mix of purchases continues to include significant purchases from the fossil generation in the Florida power market to the end of the study period and then includes RECs to offset the fossil generation purchases. A table listing the annual capacity purchases by technology for Scenario 2A can be found in Appendix H, Table 21.




Figure 24. Capacity Additions for Scenario 2A

Figure 25 summarizes Scenario 2A's annual costs, LCOE with no escalation, and LCOE with a 3% annual escalation for the 28 years to 2050. The LCOE of this net-zero carbon scenario with no escalation, \$88/MWh, is 15% lower than Scenario 1A, \$103/MWh.




Figure 25. Annualized Cost of Energy and LCOE: Scenario 2A Based on 2023–2050

Figure 26 uses the same annual costs stream to summarize Scenario 3A annual costs, LCOE with no escalation, and LCOE with a 3% annual escalation for the 20 years to 2042.




Figure 26. Annualized Cost of Energy and LCOE: Scenario 2A Based on 2023–2042



6.3 Target 3: 80% Renewable by 2035 and 100% by 2050

The chart shown in Figure 27 summarizes the technologies and capacities selected by the pIRP model for Scenario 3A, which focused on achieving 80% renewable by 2035 and 100% by 2050. The technologies selections are identical to Scenario 1A, except they added a more rapid pace in the first years of the analysis to reach the 80% renewable goal by 2035, versus Scenario 1, which does not reach 80% renewables until 2045, 10 years later. A table listing the annual capacity purchases by technology for Scenario 3A can be found in Appendix H, Table 22.




Figure 27. Capacity Additions for Scenario 3A

Figure 28 summarizes Scenario 3A's annual costs, LCOE with no escalation, and LCOE with a 3% annual escalation for the 28 years to 2050. Note that the LCOE for this scenario, \$101/MWh, is very similar to the \$103/MWh LCOE value of Scenario 1A. Figure 29 uses the same annual costs stream to summarize Scenario 3A's annual costs, LCOE with no escalation, and LCOE with a 3% annual escalation for the 20 years to 2042. The 20-year LCOE for Scenario 3A, \$90/MWh, is only \$2/MWh, or 2% over the equivalent value for Scenario 1A, \$88/MWh.




Figure 28. Annualized Cost of Energy and LCOE: Scenario 3A Based on 2023–2050




Figure 29. Annualized Cost of Energy and LCOE: Scenario 3A Based on 2023–2042

Figure 30 summarizes Scenario 3D's resulting costs for the 28 years to 2050. Scenario 3D incorporated the low fuel cost estimate, which substantially lowered the early year costs in the scenario when natural gas fueled generation dominate the supply portfolio. Figure 31 uses the same annual costs stream to



summarize Scenario 3D's annual costs, LCOE with no escalation, and LCOE with a 3% annual escalation for the 20 years to 2042.




Figure 30. Annualized Cost of Energy and LCOE: Scenario 3D Based on 2023–2042




Figure 31. Annualized Cost of Energy and LCOE: Scenario 3D Based on 2023–2042



6.4 Target 4: 80% Renewable by 2035, 100% by 2050, and Storm Resiliency

Target 4 was created at the request of CWP to assess the costs of additional resources required for the portfolio defined in Scenario 3A should solar PV resources become unavailable for a multi-day period, such as during a hurricane or other severe weather event. To estimate the impacts of a severe weather event, Quanta Technology assumed that CWP would be without any solar production for a four-day period. The solar energy during this period would then need to be replaced with energy from other resources. For Scenario 4A, the solar PV production was replaced with energy from additional battery capacity acquired by CWP through PPAs. The second scenario, 4B, assumed that PPAS would supply replacement energy with older and less efficient fossil fuel units. Quanta Technology further assumed there would be multiple years with storm events requiring the replacement energy, which occurred in four years: 2023, 2035, 2042, and 2050. Since CWP is adding more solar generation to achieve progress toward its goals of 80% renewable energy by 2035 and 100% by 2050, each subsequent year requires increasing quantities of replacement energy during the storm events to replace the increasing amount of solar PV energy purchased by CWP.

The results for Scenario 4A for 28 years and 20 years are shown in Figure 32 and Figure 33. The cumulative impacts of the additional battery storage in Scenario 4A result in a higher overall LCOE than Scenario 3A (\$115/MWh for 4A vs. \$101/MWh for 3A, both for the 28-year analysis).




Figure 32. Annualized Cost of Energy and LCOE: Scenario 4A (Battery Capacity) Based on 2023–2050




Figure 33. Annualized Cost of Energy and LCOE: Scenario 4A (Battery Capacity) Based on 2023–2042

The results for Scenario 4A for 28 years and 20 years are shown in Figure 32 and Figure 33. The 28-year LCOE results for Scenarios 4A and 4B are virtually identical (\$115.30 /MWh versus \$114.80 for 4B).




Figure 34. Annualized Cost of Energy and LCOE: Scenario 4B (Old Fossil Capacity) Based on 2023–2050



However, the 20-year LCOE results for Scenario 4B with fossil capacity used for resiliency are lower than the costs of the batteries used for resiliency in Scenario 4A (\$99/MWh for 4B versus \$113/MWh for 4A).




Figure 35. Annualized Cost of Energy and LCOE: Scenario 4B (Old Fossil Capacity) Based on 2023–2042

6.5 Summary of All Scenarios

Figure 36 summarizes the PVRR results for all the scenarios, the full 28-year PVRR, and the PVRR results for only the first 20 years of the analysis. The 28-year PVRR results show that the CWP projected costs, using a simple 3% escalation of the 2022 power costs are in the same range as Scenarios 1A, 2A and 3A which used similar fuels costs projections. Scenarios 1F, 2E, and 3D used a low fuel costs which is more consistent with current natural gas fuel price projections.

However, the 20-year PVRR results show a very tight range of costs. In the 20-year PVRR results, the difference between the forecast CWP costs (\$504/MWh) and the average of Scenario 1 variations (\$505/MWh) and the average of the Scenario 3 variations (\$498/MWh) is only 1%. Scenario 2 variations provide the lowest average LCOE (\$479/MWh), but the Scenario 1 variation average is still only 5% lower than the current CWP costs and the Scenario 1 variation.




Figure 36. Summary of 28-Year and 20-Year PVRR Results for All Scenarios



Following the presentation of the initial draft results, CWP requested that Quanta Technology focus on the results from the Low natural gas price projections which aligns better with the long term historical costs experienced by CWP. Figure 37 provides a graphical comparison of the results of Scenario 3D power costs, which incorporates a Low fuel cost projection, and the 2023 actual CWP power costs, the projected 2024 costs, then subsequent years are escalated at 3% per year. The two alternatives track very closely for the first 10 to 12 years of the analysis. After 2035, the Scenario 3D costs begin to escalate at a slightly higher rate until 2049, when the green hydrogen fueled combustion turbines are added.




Figure 37. Comparison of Annual Power Costs for Scenario 3D and CWP Escalated





7 CONCLUSIONS AND RECOMMENDED ROADMAP

7.1 Conclusions

During the study, CWP informed Quanta Technology that their primary interest had evolved to a focus on zero carbon resources and renewables (Targets 1 and 3) rather than the net-zero option (Target 2) that would allow the continuation of energy supply from carbon-emitting energy resources. With this refined focus by CWP, this section focuses only on the conclusions related to the scenarios for Targets 1 and 3.

While this study defined a proxy cost estimate for CWP's continuing path of purchasing from energy sources that include a substantial portion of carbon-producing technologies, Quanta Technology believes the proxy of a 3% escalation in costs maybe optimistically low. The actual costs can be expected to be higher if world issues in Ukraine and the Middle East continue to inflict uncertainty on the world fuel markets. However, assessing optimistically low projections of CWP costs for comparison with the results of this study is consistent with the intent of this study to determine the feasibility of the targets under consideration (i.e., if the costs of a renewable transition are acceptable in comparison to an optimistically low CWP costs, then they will be more favorable against higher CWP costs projections).

This analysis indicates that CWP's adoption of a path toward 100% renewables can be accomplished for a reasonable cost of power for the next 20 years. However, beyond the next 20 years (i.e., during the last 8 years analyzed in this report, 2043–2050), the technology selection and the costs remain understandably more uncertain and, based on the technologies options and costs assumed in this study, could bring a substantial increase in CWP's power costs. As noted earlier, the rapid rise in costs near the end of the study period was driven by assumptions on technology costs and availability, which drove the inclusion of green hydrogen-powered CTs in the resource mix and the associated rise in costs.

Quanta Technology believes that additional cost-effective technologies will be available well before 2043. The power industry is expending considerable time and money on identifying options that could deliver lower-priced energy sources, including offshore wind, long-term energy storage technologies, and new technologies for geothermal energy, among others. While the costs projected in the last 6 years of the study are very high, based on the current assumptions, the costs before 2043 are comparable to projected CWP costs and could be lower. CWP should not avoid adopting its renewable targets because of costs that are not expected to occur for over 20 years. CWP should regularly reevaluate its targets and plans for its electric energy supply. Should continuing on a path to 100% renewable prove too costly in future years, CWP can adjust accordingly.

7.2 Recommended Roadmap

This study provides results indicating that Targets 1 and 3 are viable technical and financial options for the next 20 years (i.e., 2023–2042). After 2043, the costs begin to increase substantially due to the recommended additions of CT-hydrogen resources, a high-cost and nascent technology. Based on these results, Quanta Technology recommends the following roadmap for CWP's future.



7.2.1 Initial 6 Months (July 2023–December 2023)

Within the next three months, Quanta Technology recommends that CWP focus on alignment, definition, and goal-setting/validation activities in the near term. Specifically, the following is recommended:

Table 12. Three-Month Recommendations

Actions	Projects
Define a clear target for CWP's clean energy supply	• CWP would need to coalesce around a clear target for its future clean energy supply. • Establish multiple interim targets for renewable contributions before 2050 by using the findings of this report. An illustrative example of renewable goals to achieve Targets 1 and 2 is shown in Figure 38.
Start CWP IRP program	• Assign an existing employee or hire a program manager to coordinate all aspects of reaching the goal. • Reporting templates should be developed • A timeframe for reporting to citizens should be established.

For example, some potential annual renewable targets may be considered below.




Figure 38. Illustrative Annual Renewable Targets

7.2.2 Next 18 Months (by June 2025)

Within the next 18 months, Quanta Technology recommends that CWP focus its attention on TOU, DR, and EE and prioritize utility-scale renewable purchases over rooftop solar for PV assets, as well as a number of other actions. Specifically, the following is recommended:

Table 13. 18-Month Recommendations

Actions	Projects
Develop TOU, DR, and EE programs	- Complete a load research study and consider and appliance saturation survey to gather better data to assess and design TOU, EE, and DR programs for CWP, Residential, and Business customers. - Develop forecasts of the load impacts of the future appliance and end-use electrification.



Actions	Projects
Prioritize utility-scale renewable purchases over solar PV on city rooftops	• Utility-scale solar project ownership: prioritize project and PPA negotiations to support CWP's choice of renewable target plan. • Continue to look for opportunities to pool CWP requirements and partner with FMPA and other Florida utilities for renewable and storage project power purchases and project development. • Complete a study of all CWP assets to prioritize which CWP facilities should or should not be included in future plans to add solar and storage to CWP assets. Consider an RFI for City-owned assets to understand costs and options for all possible facilities. • Complete an EV adoption study better to quantify the expected impacts of EV adoption in CWP.
Analyze warehouse rooftop PV installation	• Understand the need for individual building monitoring • Create a roadmap for monitoring and control. • Engage in discussions with vendors to develop an understanding of software in the marketplace.
Explore CWP utility bill financing	• Explore avenues in which CWP guarantees can help with financing solar of customer rooftop solar and storage additions. • Create a billing template to reflect customer savings and contribution to the goal.
Plan CWP IRP updates	• Consider assigning a project manager to provide regular updates on the program • Update the current plan to complete a revised CWP IRP after the development of EE and DR programs are developed and results from the load research study are available. • Commit to regular, periodic updates of IRP, which include a resource technology maturity assessment of new and existing technologies to provide information to adapt CWP's plan to evolving technology capabilities and costs.

7.2.3 Next 48 Months (by June 2027)

Within the next 48 months, Quanta Technology recommends that CWP focus on implementing programs (EE and TOU). Specifically, the following is recommended:



Table 14. 48-Month Recommendations

Actions	Projects
Update IRP and technology maturity assessments	• Create a roadmap for technology upgrades such as DERM to support CWP. • Create a roadmap for the implementation of CWP-owned Battery Storage for resiliency.
Create a plan for CWP vehicle electrification	• Complete a study and plan for the electrification of all CWP-owned vehicles.
Implement rate changes	• Create and implement TOU rates with energy costs and demand rates that represent actual energy and demand costs. • Change the NEM rate credited to customers to a cost-based TOU rate that evolves as CWP TOU costs evolve. • New future NEM credit for any excess flow from the customer back to the system should reflect only the actual TOU wholesale energy value to CWP. • The value of NEM backflow power from distributed solar will ultimately go to zero and be of negative value in future years as CWP wholesale solar production exceeds noontime CWP demand, after which CWP will need to purchase energy storage to store the excess solar or interrupt the excess solar.

7.2.4 Beyond 48 Months (Beyond June 2027)

Quanta Technology recommends that CWP follow the course of action with regular project management updates on meeting the renewable targets adopted in Section 7.2.1.



APPENDIX A: TERMS AND DEFINITIONS

Table 15. Report Terms

Term	Definition
100% Renewable	All energy originates from some form of renewable technology.
Bioenergy or Biomass	- Energy technologies that use biomass as a fuel. - Biomass is a solid or gaseous renewable energy resource derived from plant- and algae-based materials that include: - Crop wastes - Forest residues - Purpose-grown grasses - Woody energy crops - Microalgae - Urban wood waste - Food waste - Even though biofuels are considered renewable, burning biofuels emit carbon and other elements. - When burned as a fuel for electric production, biofuels only release the carbon the plants take from the air and soil during their growth cycle. The process is comparable to moving carbon in and out of the atmosphere and soil but does not contribute incremental increases to the atmospheric carbon. - The biomass energy technologies considered in this study are dispatchable, and their ability to operate continuously, just like a fossil-fueled plant, is only limited by the continuity of the fuel supply to the site and onsite fuel storage.
Electrification	The process of changing appliances and end uses that use fossil fuels to electric, e.g., changing a natural gas space heater to an electric heat pump or changing a gasoline-fueled vehicle to an electric vehicle.
Energy Neutral	A CWP or customer facility that generates sufficient annual energy from their distributed energy resources to offset the annual consumption of the facility.
Green Hydrogen	- Green hydrogen is considered a green and renewable fuel source. Green hydrogen is created without emissions or the use of fossil fuels. The typical method considered the likely future source of large quantities of green hydrogen is renewable energy resources supplying power to electrolyzers that split water into pure oxygen and pure hydrogen. - Green hydrogen differs from other types of hydrogen that use different fossil-fueled processes to separate hydrogen from the fuel source.
Net Energy Metering	A rating program currently in effect in CWP where customers with distributed energy resources are credited at full retail, variable rates for any excess energy (i.e., the energy that exceeds the customer's instantaneous needs) that flows back into the CWP system.
Net-Zero Carbon	Net zero refers to a state in which the greenhouse gases going into the atmosphere are balanced by removal from the atmosphere. Generally, utilities plan to achieve net-zero carbon by reducing their carbon emissions and acquiring renewable energy credits or other carbon offsets, which counterbalance carbon removal of any remaining carbon emissions resulting from their electric energy production.
Net-Zero Energy	Sufficient energy is produced from solar PV or other renewable sources to offset the annual energy consumption.



Term	Definition
Renewable Energy	• Energy is generated only from technologies considered to be renewable, including wind, solar, ocean energy, geothermal, hydroelectricity, technologies that burn fuels derived from biomass, and green hydrogen (i.e., hydrogen generated from processes that use water and renewable energy). • Hydroelectricity is a renewable technology but is treated differently than other forms of renewable energy in some states due to its other environmental impacts.
Renewable Energy Credit	• A renewable energy credit (REC) is a market-based instrument that represents the property rights to the environmental, social, and other non-power attributes of renewable electricity generation. • RECs are issued when one megawatt-hour (MWh) of electricity is generated and delivered to the grid from a renewable energy resource. • The ownership of the REC is a certificate that can be owned, sold, or traded separately from the electrical energy that served as the source of the REC creation.
Virtual Power Plant	• Refers to a group of distributed generation or energy storage resources that can be controlled and dispatched by the utility to mimic both the electric capacity and flexibility of a typical utility generation plant or utility energy storage plant.
Zero Carbon	• All energy is created with technologies that do not emit carbon into the atmosphere. • “Real Zero” is a new term recently invented and trademarked by FPL to differentiate its emission goal from other utilities’ net-zero carbon goals. However, Real Zero is identical in definition to zero carbon. • For electric generation, zero-carbon energy resources include all forms of generation technology that do not emit carbon (e.g., nuclear and renewable technologies that do not emit carbon into the atmosphere). • Even though biofuels and geothermal are considered renewable, they are not zero-carbon resources since both generally emit carbon into the atmosphere.



APPENDIX B: LIST OF ABBREVIATIONS AND ACRONYMS

Table 16. Report Abbreviations and Acronyms

Term	Definition
ATB	NREL Annual technology baseline
Biomass	Biomass fuel generation
CAPEX	Capital expenditures
CapPurch	Capacity purchases from the Florida energy market, which is assumed to be 100% fossil generation
CE	Internal Combustion Engine fueled with diesel
CT	Combustion turbine generator
CT-Hydrogen	Green hydrogen-fueled combustion turbine
CWP	City of Winter Park
DEF	Duke Energy Florida
Dsolar-CommGround	Distributed solar PV at CWP facility open land
Dsolar-CommRoof	Distributed solar PV on CWP facility rooftops
DR	Demand response
EE	Energy efficiency
EES-4	Battery electric energy storage system with a 4-hour energy capacity
ELCC	Effective load-carrying capability
EV	Electric vehicle
FGBC	Florida Green Building Coalition
FL	Florida
FMPA	Florida Municipal Power Agency
FPL	Florida Power & Light
FY	Fiscal year
GHG	Greenhouse gas
GRU	Gainesville Regional Utilities
GW	Gigawatt
IBR	Inverter-based resources
IRP	Integrated resource plan
pIRP	Probabilistic integrated resource plan
JEA	Jacksonville Electric Authority
KW	Kilowatt
LCOE	Levelized cost of energy
LDV	Light-duty vehicle



Term	Definition
LED	Light emitting diode
LP	Linear program
MW	Megawatt
NREL	National Renewable Energy Laboratory
OUC	Orlando Utilities Commission
PPA	Power purchase agreement
PSC	Public Service Commission
PV	Photovoltaic
REC	Renewable energy credit
RPS	Renewable portfolio standards
SAP	Sustainable action plan
SFH	Single-family homes
T&D	Transmission & Distribution
TAL	Tallahassee
TECO	Tampa Electric Company
TYSP	Ten-year site plan
USolar	Utility-scale solar PV
VRE	Variable renewable energy



APPENDIX C: BATTERY LIFECYCLE CONSIDERATIONS

Two key factors dictate the life of battery-based energy storage systems:

- Capacity fading due to age
- Capacity fading due to charge-discharge cycles

Lithium-ion storage capacity typically fades or degrades with time and use, at 2%–3% per year, if used at an average rate of one full cycle per day. The storage system is designed to deliver a maximum lifetime of around 4000–6000 full cycles before the capacity fades below 70%–80% of its initial capacity. The number of cycles a battery system delivers depends strongly on the depth of discharge in each cycle. The lifecycles increase as the cycle depth of discharge decreases. In addition to lifecycles, lithium-ion batteries typically have a shelf life of around 15 years.

To maintain a battery over its life, operators usually implement an asset management plan that includes annual inspections and capacity augmentations.

However, its modules must be replaced and recycled at the end of a battery system's life. Many components of the battery systems will remain functional, including the housing/containers, electrical balance of the plant, and interconnections. The bi-directional inverters are also replaced every 10–15 years.

The chemistry of lithium-ion batteries differs between technologies and manufacturers. Some use toxic compounds and rare metals (such as cobalt or cadmium), while others use safer, non-toxic, and relatively common materials (such as manganese oxide or phosphate). Unlike lead-acid batteries that recycle 100% of the lead used in their ecosystem, the state of recycling lithium-ion batteries is still evolving. Recycling uses complex and energy-demanding processes that include pyrometallurgy and hydrometallurgy. In pyrometallurgy, battery components are smelted in a high-temperature process that burns and separates a mixed metal alloy of cobalt, copper, iron, and nickel. Hydrometallurgy recovers the desired metals by treating the cathode material with an acidic or basic solution. Multiple companies throughout North America are already in the business of reusing or recycling batteries, and many of these have partnered with car companies to aid in the recycling of their electric vehicle batteries. Most companies specializing in this process claim to recover up to 95% of the raw materials, including cobalt, nickel, and lithium. Tesla also recycles batteries independently, claiming to recover 92% of the battery's raw materials.

From a financial point of view, the cost of recycling after 15 years is not certain. Assuming a value of at least \$50/kWh in today's dollars is prudent.



APPENDIX D: NREL PVWATTS SOLAR PRODUCTION ESTIMATE




Figure 39. PVWatts Calculator



Location and Station Identification

Requested Location	401 S Park Ave 32789		
Weather Data Source	Lat, Lng: 28.61, -81.34	1.2 mi	
Latitude	28.61° N		
Longitude	81.34° W		

PV System Specifications

DC System Size	13.8 kW												
Module Type	Standard												
Array Type	Fixed (open rack)												
System Losses	14.08%												
Array Tilt	30°												
Array Azimuth	180°												
DC to AC Size Ratio	1.2												
Inverter Efficiency	96%												
Ground Coverage Ratio	0.4%												
Albedo	From weather file												
Bifacial	No (0)												
Monthly Irradiance Loss	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	
	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Performance Metrics

DC Capacity Factor	17.2%
--------------------	-------

Figure 40. PVWatts Information and Metrics



APPENDIX E: RESIDENTIAL ROOFTOP SOLAR AND BATTERY FORECASTS

Table 17. Residential Rooftop Solar PV And Battery Forecasts

Year	Expected		High		Low	
	Residential Distributed Solar (MWh)	Residential Battery (MWh) ¹⁴	Residential Distributed Solar (MWh)	Residential Battery (MWh) ¹⁵	Residential Distributed Solar (MWh)	Residential Battery (MWh) ¹⁵
2025	650	5	1,037	8	387	0
2026	1,297	7	2,069	11	772	0
2027	2,591	8	4,132	13	1,542	0
2028	3,878	10	6,186	16	2,308	0
2029	5,809	12	9,266	19	3,457	0
2030	7,730	13	12,330	21	4,601	0
2031	10,291	15	16,417	24	6,126	0
2032	12,840	17	20,483	27	7,643	0
2033	15,376	18	24,528	29	9,152	0
2034	18,550	20	29,591	32	11,041	0
2035	21,707	22	34,628	35	12,920	0
2036	25,499	23	40,676	37	15,177	0
2037	29,922	25	47,732	40	17,810	0
2038	34,973	27	55,789	43	20,816	0
2039	39,349	28	62,769	45	23,421	0
2040	43,052	30	68,678	48	25,625	0
2041	46,087	32	73,519	51	27,432	0
2042	49,107	33	78,336	54	29,229	0
2043	51,462	35	82,093	56	30,631	0
2044	53,805	37	85,830	59	32,025	0
2045	55,486	38	88,512	62	33,026	0
2046	57,159	40	91,181	64	34,022	0
2047	58,823	42	93,836	67	35,012	0
2048	59,829	43	95,440	70	35,611	0
2049	60,830	45	97,037	72	36,207	0
2050	60,526	47	96,552	75	36,026	0

¹⁴ Battery energy forecasts are based on 80% of rated battery energy capacity.



APPENDIX F: FORECAST OF ROOFTOP AND GROUND MOUNT SOLAR PV ON CWP-OWNED PROPERTY

Table 18. Forecast Of Rooftop And Ground Mount Solar PV On CWP-Owned Property

Year	Expected	
	CWP-Owned Property Rooftop PV (MWh)	CWP-Owned Property Ground Mount PV (MWh)
2025	0	0
2026	0	0
2027	1,780	0
2028	1,780	0
2029	1,780	0
2030	1,780	0
2031	1,780	1,780
2032	1,780	1,780
2033	1,780	1,780
2034	1,780	1,780
2035	1,780	1,780
2036	1,780	2,735
2037	1,780	2,735
2038	1,780	2,735
2039	1,780	3,612
2040	1,780	5,353
2041	1,780	5,353
2042	1,780	5,353
2043	1,780	5,353
2044	1,780	5,353
2045	1,780	5,353
2046	1,780	5,353
2047	1,780	5,353
2048	1,780	5,353
2049	1,780	5,353
2050	1,780	5,353



APPENDIX G: RESIDENTIAL LDV EV FORECASTS

Table 19. Residential LDV EV Forecasts

Year	Expected		High		Low	
	Resident-Owned LDV EV	Resident LDV EV Charging Energy (MWh)	Resident-Owned LDV EV	Resident LDV EV Charging Energy (MWh)	Resident-Owned LDV EV	Resident LDV EV Charging Energy (MWh)
2023	403	797	624	1,235	302	597
2024	542	1,224	840	1,898	407	918
2025	714	1,766	1,107	2,737	536	1,325
2026	942	2,483	1,460	3,849	707	1,862
2027	1,222	3,381	1,894	5,240	917	2,536
2028	1,556	4,469	2,413	6,927	1,167	3,352
2029	1,953	5,775	3,026	8,951	1,464	4,331
2030	2,417	7,327	3,747	11,356	1,813	5,495
2031	2,799	8,638	4,569	14,100	2,211	6,822
2032	3,241	10,002	5,430	16,757	3,191	9,848
2033	3,753	11,582	6,453	19,915	4,172	12,874
2034	4,346	13,411	7,670	23,669	5,152	15,900
2035	5,032	15,529	9,115	28,130	6,133	18,926
2036	5,827	17,981	10,833	33,431	7,113	21,952
2037	6,747	20,821	12,875	39,732	8,094	24,977
2038	7,812	24,109	15,301	47,221	9,074	28,003
2039	9,046	27,917	18,185	56,121	10,055	31,029
2040	10,475	32,326	21,613	66,698	11,035	34,055
2041	12,129	37,431	21,651	66,816	12,016	37,081
2042	14,044	43,342	21,689	66,934	12,996	40,107
2043	16,262	50,186	21,728	67,052	13,977	43,132
2044	18,831	58,112	21,766	67,171	14,957	46,158
2045	21,804	67,289	21,804	67,289	15,938	49,184
2046	21,843	67,408	21,843	67,408	16,918	52,210
2047	21,882	67,527	21,882	67,527	17,899	55,236
2048	21,920	67,647	21,920	67,647	18,879	58,262
2049	21,959	67,766	21,959	67,766	19,860	61,287
2050	21,998	67,886	21,998	67,886	20,840	64,313



APPENDIX H: ANNUAL SCHEDULE OF CAPACITY PURCHASES

Table 20. Scenario 1A: Annual Capacity Purchases (MW)

Year	Utility Scale Solar (Usolar)	4-hr Battery Energy Storage System (ESS-4)	Biomass	Internal Combustion Engine - Fossil (CE)	Hydrogen Fuel Combustion Turbine (CT Hydrogen)	Demand Response (DR)	Energy Efficiency (EE)	City Property Rooftop Solar (Dsolar-Comm Roof)	City Property Ground Mount Solar (Dsolar-Comm Ground)	FL System Purchase (Cap Purch)
2023	20.0	0.0	15.0	5.0	0.0	5.0	3.0	0.0	0.0	75.5
2024	20.0	0.0	15.0	5.0	0.0	5.0	4.0	0.0	0.0	74.7
2025	20.0	0.0	15.0	5.0	0.0	5.0	5.0	0.0	0.0	73.7
2026	20.0	0.0	15.0	5.0	0.0	5.0	5.0	0.0	0.0	73.4
2027	20.0	0.0	15.0	5.0	0.0	5.0	5.0	1.0	0.0	73.1
2028	20.0	0.0	15.0	5.0	0.0	5.0	5.0	1.0	0.0	72.9
2029	20.0	0.0	15.0	5.0	0.0	5.0	5.0	1.0	0.0	72.4
2030	30.8	0.0	15.0	5.0	0.0	5.0	5.0	1.0	0.0	70.3
2031	38.4	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	68.2
2032	56.1	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	64.8
2033	64.4	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	62.7
2034	70.8	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	60.7
2035	70.8	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	59.7
2036	70.8	20.0	15.0	5.0	0.0	5.0	5.0	1.0	2.0	49.1
2037	70.8	40.0	15.0	5.0	0.0	5.0	5.0	1.0	2.0	39.4
2038	70.8	60.0	15.0	5.0	0.0	5.0	5.0	1.0	2.0	30.3
2039	70.8	76.4	15.0	5.0	0.0	5.0	5.0	1.0	3.0	23.0
2040	70.8	93.7	15.0	5.0	0.0	5.0	5.0	1.0	3.0	15.4
2041	89.3	93.7	15.0	5.0	0.0	5.0	5.0	1.0	3.0	13.8
2042	89.8	93.7	15.0	5.0	0.0	5.0	5.0	1.0	3.0	15.0
2043	89.8	93.7	15.0	5.0	0.0	5.0	5.0	1.0	3.0	16.3
2044	89.8	93.7	15.0	5.0	0.0	5.0	5.0	1.0	3.0	17.8
2045	89.8	93.7	15.0	5.0	6.8	5.0	5.0	1.0	3.0	13.0
2046	89.8	93.7	15.0	5.0	7.4	5.0	5.0	1.0	3.0	13.2
2047	89.8	93.7	15.0	5.0	7.4	5.0	5.0	1.0	3.0	13.9
2048	89.8	93.7	15.0	5.0	7.4	5.0	5.0	1.0	3.0	14.5
2049	89.8	93.7	15.0	5.0	16.2	5.0	5.0	1.0	3.0	7.0
2050	78.9	93.7	15.0	0.0	41.2	0.0	5.0	1.0	3.0	0.0



Table 21. Scenario 2A: Annual Capacity Purchases (MW)

	Utility Scale Solar (Usolar)	Biomass	Internal Combustion Engine - Fossil (CE)	Renewable Energy Credits (REC)	Hydrogen Fuel Combustion Turbine (CT Hydrogen)	Demand Response (DR)	Energy Efficiency (EE)	City Property Rooftop Solar (Dsolar- Comm Roof)	City Property Ground Mount Solar (Dsolar- Comm Ground)	FL System Purchase (Cap Purch)
2023	20.0	15.0	5.0	0.0	0.0	5.0	3.0	0.0	0.0	75.5
2024	20.0	15.0	5.0	0.0	0.0	5.0	4.0	0.0	0.0	74.7
2025	20.0	15.0	5.0	0.0	0.0	5.0	5.0	0.0	0.0	73.7
2026	20.0	15.0	5.0	0.0	0.0	5.0	5.0	0.0	0.0	73.4
2027	20.0	15.0	5.0	0.0	0.0	5.0	5.0	1.0	0.0	73.1
2028	20.0	15.0	5.0	0.0	0.0	5.0	5.0	1.0	0.0	72.9
2029	20.0	15.0	5.0	14.1	0.0	5.0	5.0	1.0	0.0	72.4
2030	20.0	15.0	5.0	29.9	0.0	5.0	5.0	1.0	0.0	71.9
2031	20.0	15.0	5.0	43.7	0.0	5.0	5.0	1.0	1.0	71.0
2032	20.0	15.0	5.0	68.7	0.0	5.0	5.0	1.0	1.0	70.2
2033	20.0	15.0	5.0	84.5	0.0	5.0	5.0	1.0	1.0	69.4
2034	20.0	15.0	5.0	105.5	0.0	5.0	5.0	1.0	1.0	68.3
2035	20.0	15.0	5.0	121.4	0.0	5.0	5.0	1.0	1.0	67.3
2036	20.0	15.0	5.0	146.9	0.0	5.0	5.0	1.0	2.0	66.7
2037	20.0	15.0	5.0	176.6	0.0	5.0	5.0	1.0	2.0	67.0
2038	20.0	15.0	5.0	192.6	0.0	5.0	5.0	1.0	2.0	68.0
2039	20.0	15.0	5.0	208.3	0.0	5.0	5.0	1.0	3.0	68.8
2040	20.0	15.0	5.0	225.0	0.0	5.0	5.0	1.0	3.0	69.9
2041	20.0	15.0	5.0	242.5	0.0	5.0	5.0	1.0	3.0	71.0
2042	20.0	15.0	5.0	260.9	0.0	5.0	5.0	1.0	3.0	72.3
2043	20.0	15.0	5.0	280.4	0.0	5.0	5.0	1.0	3.0	73.6
2044	20.0	15.0	5.0	300.9	0.0	5.0	5.0	1.0	3.0	75.1
2045	20.0	15.0	5.0	323.7	0.0	5.0	5.0	1.0	3.0	76.7
2046	20.0	15.0	5.0	340.1	0.0	5.0	5.0	1.0	3.0	77.4
2047	20.0	15.0	5.0	341.0	0.0	5.0	5.0	1.0	3.0	78.1
2048	20.0	15.0	5.0	345.8	0.0	5.0	5.0	1.0	3.0	78.8
2049	20.0	15.0	5.0	361.9	0.0	5.0	5.0	1.0	3.0	79.4
2050	20.0	15.0	5.0	412.1	0.0	5.0	5.0	0.0	1.5	80.4



Table 22. Scenario 3A: Annual Capacity Purchases (MW)

Year	Utility Scale Solar (Usolar)	4-hr Battery Energy Storage System (ESS-4)	Biomass	Internal Combustion Engine - Fossil (CE)	Hydrogen Fuel Combustion Turbine (CT Hydrogen)	Demand Response (DR)	Energy Efficiency (EE)	City Property Rooftop Solar (Dsolar-Comm Roof)	City Property Ground Mount Solar (Dsolar-Comm Ground)	FL System Purchase (Cap Purch)
2023	20.0	0.0	15.0	5.0	0.0	5.0	3.0	0.0	0.0	75.5
2024	20.0	0.0	15.0	5.0	0.0	5.0	4.0	0.0	0.0	74.7
2025	20.0	0.0	15.0	5.0	0.0	5.0	5.0	0.0	0.0	73.7
2026	20.0	0.0	15.0	5.0	0.0	5.0	5.0	0.0	0.0	73.4
2027	20.0	0.0	15.0	5.0	0.0	5.0	5.0	1.0	0.0	73.1
2028	20.0	0.0	15.0	5.0	0.0	5.0	5.0	1.0	0.0	72.9
2029	35.7	0.0	15.0	5.0	0.0	5.0	5.0	1.0	0.0	70.0
2030	60.7	0.0	15.0	5.0	0.0	5.0	5.0	1.0	0.0	65.8
2031	85.7	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	61.1
2032	110.7	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	56.6
2033	133.0	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	52.4
2034	144.1	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	49.7
2035	144.1	0.0	15.0	5.0	0.0	5.0	5.0	1.0	1.0	48.7
2036	144.1	20.0	15.0	5.0	0.0	5.0	5.0	1.0	2.0	38.1
2037	144.1	40.0	15.0	5.0	0.0	5.0	5.0	1.0	2.0	28.4
2038	144.1	60.0	15.0	5.0	0.0	5.0	5.0	1.0	2.0	19.3
2039	144.1	80.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	10.2
2040	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	1.3
2041	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	2.4
2042	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	3.7
2043	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	5.0
2044	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	6.5
2045	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	8.1
2046	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	8.8
2047	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	9.5
2048	144.1	100.0	15.0	5.0	0.0	5.0	5.0	1.0	3.0	10.1
2049	128.5	100.0	15.0	5.0	12.9	5.0	5.0	1.0	3.0	1.2
2050	103.5	100.0	15.0	0.0	37.9	0.0	5.0	1.0	3.0	0.0



APPENDIX I: DAILY ENERGY SOURCES

The Scenario 1A supply mix shown below for an average summer day is typical of the other scenarios assessed. Supply is a mix of solar, fossil imports and biomass generation during the day with battery charging during the day, then stored battery energy discharged at night.




Figure 41. Energy Sources by Hour for Average Summer Week-Day - Scenario 1A, Year 2042




Figure 42. Energy Sources by Day for Average Summer Week-Day - Scenario 1A, Year 2042

Key Assumptions for Renewable Energy Study

1. In adopting these targets, the commission has assumed that the cost of renewable technologies will drop over time. Historically, emerging technologies have achieved similar reductions in cost as economies of scale and engineering advances work together. For example: the microprocessor computing power for an iPad 2 dropped from \$100,000,000 in 1980 to \$1,000,000 in 1990 to \$100 in 2010, huge reductions over 30 years; and the cost of solar power dropped from \$700 per kWh in 2010 to under \$200 per kWh in 2018, an 8-year period. See Forbes article “Declining Cost Curves Create Opportunities for Investors” 10-17-2018. There is no assurance however that the costs will decline as assumed.
2. Battery cost/kWh will drop over time
 - a. Utility Scale Battery Cost

Table 1. Battery Storage Costs for Key Milestone Years (Installed Cost - \$/kWh)

Battery Energy Storage Technology	2023	2035	2042	2050
Residential BESS–2.5 hr	\$1,443	\$1,359	\$1,359	\$1,359
Commercial BESS–4 hr	\$774	\$729	\$729	\$729
Utility Scale BESS–4 hr (ESS-4)	\$514	\$484	\$484	\$484

- b. **Error! Reference source not found.** in the IRP report summarizes the costs for Battery Storage installations.

3. Solar cost/kW will drop over time
 - a. Solar Cost per kWh

Table 2.Solar PV Costs for Key Milestone Years (Installed Cost - \$/kW)

Solar PV Technology	2023	2035	2042	2050
Residential Rooftop Solar	\$3,400	\$2,892	\$2,892	\$2,892
Commercial Solar PV, Rooftop (Dsolar-CommRoof)	\$2,121	\$1,804	\$1,804	\$1,804
Commercial Solar PV, Ground-mount (Dsolar-CommGround)	\$2,236	\$1,902	\$1,902	\$1,902
Utility Scale Solar PV (USolar)	\$1,331	\$1,253	\$1,253	\$1,253
Green Hydrogen-Fueled CT (CT-Hydrogen)	\$1,561	\$1,828	\$1,828	\$1,828
Biofuel Internal Combustion Reciprocating Engine(Biomass)	\$520	\$552	\$552	\$552

Note – While FMPA will be the source of some of the early solar contracts they may not be the provider for future contracts. The source of our future cost estimates is based on NREL and DOE data.

- b. Generation Technology cost projects

The general industry consensus is that the forecasted installed cost for solar and battery storage technologies will continue to decline in cost for the foreseeable future through continued manufacturing and solar PV performance improvements. In addition, legacy

technologies such as combustion turbines are expected to continue to increase in cost based on inflationary pressures. The NREL ATB projects cost declines in renewable technologies and battery storage and cost increases in legacy technologies through 2050. Supply disruptions and changing tariff structures resulted in an increase in solar PV costs in 2021 and 2022. These recent cost increases are expected to be temporary as the solar PV manufacturers adjust in response to the changing world market.

To remain conservative in the cost projections of future technology costs used in this study, Quanta Technology estimated a lower near-term price decline for solar PV and batteries than the NREL ATB estimate. In addition, Quanta Technology estimated the price declines would stabilize after ten years for solar PV and after five years for battery storage. Further price increases for the legacy generation technologies also had a similar end to their forecasted continuing escalation where their costs would stabilize. The combination of these adjustments to the future escalation of technology costs provides a conservatively high cost for solar PV and battery storage and a conservatively low cost for legacy technologies.

The graph shown in Figure 1 below presents the annual costs of the subset of technologies that were ultimately included in the supply portfolios described later in this report.




Figure 1. Projections of Generation and Storage Technologies Installed Costs

4. **Assumes that Underground Project will be completed by 2030** and the existing bonds will be paid off in 2036.
5. Burning garbage and trash still emits carbon and other harmful emissions, and while it reduces dependence on fossil fuels, it is not considered by most in the industry to be. On the other hand, biomass generation is considered renewable energy even though it also emits carbon and other emissions. Biomass generation is renewable since it is a carbon-neutral fuel that traps carbon from the atmosphere during its growth cycle and then releases the same amount of carbon during the combustion process. Biomass generation is assumed to be a “Dispatchable” (On-Demand) Power source available at any time of day. Even though it also emits carbon and other emissions. Biomass generation is considered renewable since it is a carbon-neutral fuel that traps carbon from the atmosphere during the growth cycle of biofuels and then releases only the same amount of carbon during the combustion process. In addition, unlike solar PV, biomass generation is generally a “dispatchable” (on-demand) power source available at any time of day.
6. Quanta Technology used PPA pricing from existing CWP contracts and other data available for Florida power costs to estimate that future purchases from the Florida grid would. Florida currently relies principally on fossil-fueled resources. However, **as FPL and other utilities evolve their system to cleaner resources the power costs from the Florida grid are estimated to escalate at 2% annually regardless of the CWP decisions for its power supply.** Quanta Technology also assumed that the purchased power market in Florida would continue to provide CWP options to purchase specific types of power from large suppliers, such as FPL, OUC, and the FMPPA.
7. In addition to “Variable Costs” of power such as the cost per kWh to buy from suppliers and the pass through of fuel costs, WPPC has “Fixed Costs” of maintaining the distribution system including the grid, power lines, and transformers. **WPPC’s Fixed Costs are expected to inflate by approximately 3%.**
8. WPPC expects that demand will increase to accommodate Electric Vehicles and will decrease as homes and businesses become more Energy Efficient.
 1. “Expected” Demand Growth Rate = 0.09%/yrs. “High” Demand Growth = 1.15%
 2. **“Expected” Energy Reduction from Energy Efficiency = 2% reduction/year for 5 years, which means that 10% less energy (compared to 2023) will be used by homes and businesses by 2028.** Efficiency comes from:
 - a. LED lighting, Heat Pumps instead of old resistance heating in Winter, better attic and wall Insulation, double pane energy efficient Windows
 - b. Distributed Batteries and Solar from residential and commercial which allows the peak energy periods to level out with [Demand Response (DR) or Demand Side Management (DSM)] programming. In other words, homes and businesses use their own batteries during the times when the most energy is needed.

9. **This study DOES NOT assume electric grid upgrades are needed or funded for larger power lines or transformers.** Evaluating the Grid requirements as Residents install more and more Solar and Battery Walls will be part of the Strategic Planning background study.
10. Hurricane Outage Management: Sizing the Batteries or planning for back-up “Dispatchable”/On-Demand power for a Hurricane Event were not part of the Consultant’s original scope. However, in a subsequent addition to the Consultant’ scope two new scenarios 4A and 4B were added to estimate the increase in supply costs of a plan that provides resiliency for the potential of four days of disruptions to the CWP solar energy supply due to a hurricane or a severe tropical storm. The costs for repeated severe events occurring in 2023, 2035, 2042, and 2050 were estimated.
- A new scenario 4A assumes the production output of all utility-scale solar PV contracted by CWP is significantly impacted for four days while all other generation sources remain unchanged. 100% of the replacement energy during severe weather events is assumed to come from batteries contracted for or owned by CWP.
 - A second new scenario 4B assumes the production output of all utility-scale solar PV contracted by CWP is significantly impacted for four days while all other generation sources remain unchanged. **The replacement energy during severe weather events is assumed to come from grid purchases from reserve units, generally older and less efficient fossil units in scenario 4B. Presumably, this premium will be recovered in the fuel cost adjustment.**

All other assumptions for the hurricane scenarios follow those defined in Scenario 3A. The results of the analysis are provided below.

Table 3.Results of Scenarios 3A, 4A and 4B

Year	Scenario 3A	Scenario 4A	Scenario 4B
20-year PVRR – 2023 to 2042 (\$M)	505	637	558
LCOE based on 20 year PVRR (\$/MWh)	90	113	99

11. Under Scenario 3A, While the Consultant recommends prioritizing Utility Scale Battery Storage over City owned ground and rooftop solar, the report assumes that the City Invests heavily in Solar Power as follows:

Table 4.Capacity and Costs of Solar PV on CWP Owned Buildings and Vacant Land

Year	Cumulative City Rooftop PV (MW)	Cumulative City Ground Mount PV (MW)	Cumulative Total MW)	Cumulative Cost (\$M)
2035	0.98	0.98	1.96	\$3.8
<u>2042</u>	<u>0.98</u>	<u>2.95</u>	<u>3.94</u>	<u>\$7.5</u>
2050	0.98	2.95	3.94	\$7.5

Currently there is no city land set aside for Ground based Solar.

However, Under Scenario 3E, there is no requirement of the City to own Solar on City Owned property. However, there is an expectation that, depending on the capacity to issue bonds and borrow for the cost of construction, the City may own Solar if the business case and benefit are deemed appropriate.

12. Assumes that the purchased power market continues to allow WPPC to purchase power from large suppliers, such as Florida Power, OUC, Florida Municipal Power Authority and independent power developers.
13. Adoption of Residential Electric Vehicles, Solar Panels, and Energy Storage/Batteries are assumed to be closely aligned and increasingly adopted as roofs and vehicles are replaced. The study expects a reduction in net energy supplied to residents. The study does NOT assume significant buyback of Solar power under net metering and does NOT assume any “Virtual Power Plant” benefits, although both may occur if “Time of Use” rates are implemented as recommended. The study assumes Residents will invest in Electric Vehicles, Roof top Solar and Batteries voluntarily at their personal cost. **By 2042, the study forecasts:**
 - **Up to 95% of the registered vehicles in CWP may be electric vehicles.**
 - **Approximately 35% of residential rooftops will have solar PV installed,** with the capacity to generate approximately 49,000 MWh of energy per year, which is approximately 11% of the total CWP requirement.
 - **Approximately 35% of residences will have battery energy storage systems (BESS) installed.**

Proforma Financial Projection Assumptions- Based on Actual History and Experience. Incorporates Cost of Electricity and estimated demand originating from the Quanta Study.

14. In the forecast for the productions costs for years 2043-2050 when Clean Hydrogen Combustion Turbine (CT-Hydrogen) begins to play an important role in the renewable energy strategy, the Commission has assumed a cost for power from a portfolio of substantially carbon free resources will average of \$133/MWh for power costs in 2042. These cost reflect the costs prior to the introduction of any costs associated with a CT-Hydrogen resource or another clean technology that could supply a firm dispatchable resource. In this analysis, the addition of the

CT-Hydrogen resource is forecast to drive the average power costs to \$255/MWh in 2050, largely due the cost forecast of clean hydrogen costs of \$366/MWh in 2050.

The Commission is unwilling at this time to accept a plan through 2050 that includes the current costs assumptions for CT-Hydrogen. At this time, the Commission can support a conditional plan that establish an upper limit to the average power costs after 2042 that would not exceed 3% escalation from the costs forecast for 2042. This 3% escalation limit would require a significant reduction in the costs of CT-Hydrogen or an alternate carbon free generation technology that could serve the same role in the City's power portfolio.

The Commission is willing to accept power costs reflecting a 3% escalation from the 2042 costs of \$133/MWh, yielding a maximum acceptable average power costs in 2050 of \$168/MWh. More specifically, **the commission adopts values for the Maximum Annualized Power costs shown in the right column of the table below.**

Table 5. Projected Power Costs

Year	Annualized Cost (\$/MWh)	Annualized Cost (\$/MWh) escalated at 3% after 2042	LCOE (\$/MWh) with a 3% escalation	Maximum Acceptable Annualized Power Costs
2023	\$72		\$70	
2024	\$72		\$73	
2025	\$72		\$75	
2026	\$74		\$77	
2027	\$75		\$79	
2028	\$77		\$82	
2029	\$78		\$84	
2030	\$77		\$87	
2031	\$76		\$89	
2032	\$80		\$92	
2033	\$84		\$95	
2034	\$89		\$97	
2035	\$91		\$100	\$91
2036	\$107		\$103	
2037	\$112		\$106	
2038	\$119		\$110	
2039	\$126		\$113	
2040	\$133		\$116	
2041	\$133		\$120	
2042	\$133	\$133	\$123	\$133
2043	\$132	\$137	\$127	

Year	Annualized Cost (\$/MWh)	Annualized Cost (\$/MWh) escalated at 3% after 2042	LCOE (\$/MWh) with a 3% escalation	Maximum Acceptable Annualized Power Costs
2044	\$131	\$141	\$131	
2045	\$127	\$145	\$135	
2046	\$131	\$150	\$139	
2047	\$136	\$154	\$143	
2048	\$140	\$159	\$147	
2049	\$138	\$164	\$152	
2050	\$255	\$168	\$156	\$168

15. Residential Revenues Average \$/kWh are based on rates effective May 1, 2023. **The baseline Proforma assumes a 3% annual cost of power increase** (which corresponds to the 3% “Cost Recovery Growth/Escalation Rate” illustrated by the orange line on Figure 30 of the study report results for Scenario 3D)
16. Commercial Revenues Average \$/kWh are based on Trailing 12 months history but have been adjusted to reflect the elimination of “Legacy Time of Use Rates” (which are carryovers from the City’s acquisition of the Power Company from Duke Power) and the current rates which became effective May 1, 2023. **The baseline Proforma assumes a 3% annual cost of power increase** (which corresponds to the 3% “Cost Recovery Growth/Escalation Rate” illustrated by the orange line on Figure 30 of the study report results for Scenario 3D).
17. No “Time of Use” or “TOU” rates are currently in effect, nor are they included in the cash flow forecast at this time. Future strategic plans will likely add TOU rates to incentivize load management.
18. Revenues include franchise fees. Revenues do NOT include Utility Taxes or Sales Taxes, which are a pass through to the city and state, respectively. Revenues include Fuel Cost Adjustments even though they are a “pass through” and are also shown as part of the Cost of Electricity expenses.
19. **Fixed Operating and Grid Costs are based on the City’s ten-year proforma for the fiscal year beginning October 1, 2023.**
20. Cost of Electricity is itemized based on source of energy. The Fuel Cost Adjustment Expense is itemized based on the source of fuel and equals the Fuel Cost Adjustment Revenue. In other words, the Fuel Cost Adjustment is an “in and out” line item.
21. Operating Transfers Out is the franchise fee and the revenue share transferred to the General Fund for general government purposes.

22. Cumulative Reserves are the working capital (current assets minus current liabilities) requirements established by the City's Administrative Policy which requires a minimum of 45 days operating expenses excluding amortization.
23. Debt Service is the principal and interest required on bonds.
24. Capital Projects include the undergrounding project and other construction projects. Inventory Purchases are for major equipment and supplies such as transformers. Replacement Reserves are reserves set aside for periodic replacement of capitalized equipment, systems and building components.
25. **Investment in or Debt Service on Renewable Energy generation or storage. This includes construction of City owned solar; construction of City owned Battery storage systems; debt service on "green bonds" issued to construct city owned assets; co-investment in joint ventures that will own renewable energy generation or storage. This does not include long term purchase power commitments.**
26. **The Baseline Budget and Proforma financial projections both assume the same amortization of the CWP debt incurred to finance the undergrounding of the CWP distribution system. with the existing bonds paid off in 2036.**

EDITS REQUESTED TO STUDY, BEFORE VOTING ON RESOLUTION AND CHANGES:

✓ = Encumbered Under New SOW for Quanta and Completed

- ✓ Cash Flow Presentation with:
 - Revenue Forecast showing Residential and Commercial revenues matching the Scenario 3A (and 3E) using existing average charges per kwh and Fuel Cost Pass Through
 - Fixed, Operating and Grid Costs per recent Cost Analysis
 - Cost of Electricity per Scenario 3A and 3E
 - Subtotal- Operating Profit
 - Transfers to Affiliates/General Fund and Franchise Fees
 - Subtotal- Cash Flow Available for Debt Service and Investment
 - Required Deposits to Electric Company Reserves
 - Debt Service
 - Capital Projects and Purchase of Inventory (itemize Undergrounding and specific projects greater than \$1 million per year)
 - Total- Excess Cash Flow/Retained Earnings
 - Include the ability to inflate/escalate individual line items. E.g. may want to be able to increase/decrease residential and commercial rates per kwh separately. Not intended to be a detailed rate model- see Strategic Plan/Business Plan below
- ✓ Create a Scenario 3E that excludes any City Owned Solar City's owned solar as the recommendation is to prioritize utility scale solar. Zero out the City Solar assumed in Appendix F in effort that City Owned solar can take place in the normal 5/10/25 year investment/capital planning, instead of being a target in and of itself.
- A ball park cumulative cost to produce the City owned solar in Appendix F of study. Pending
- ✓ Cost Recovery Growth Rate notation for the escalator and cost per KWH for CT- Hydrogen added.
- ✓ Key Assumptions review by Quanta, including: Overview of Hurricane Event Options and Industry Trends.

EDITS REQUESTED TO SAP:

✓ = Completed

- Addition of "Key Assumptions" as an appendix to the Sustainability Plan including notes the \$120/Mkwh target in 2042 target as the path to achieving 100% based on technology that doesn't exist today. Add footnote to CR-1 once Key Assumptions are added to appendix to read "... as noted in the Key Assumptions Appendix." Pending
- ✓ Assumption footnote for the 2050/100% goal.
- ✓ Add footnote regarding the undergrounding that states the target completion date is no later than 2030, even though it shows up in the 2035 column.

- ✓ Adjust E-1 and E-2 targets on energy efficiency and carbon reduction to line up with the Quanta report to include footnote to Key Assumptions appendix.

PRIORITY PROJECTS NEXT 1-2 MONTHS:

- ✓ Citizens slide deck and info-graphical educational brochure
- ✓ Preview by Quanta of Key Assumption appendix
- ✓ IRP Program Manager job posting and recruitment
- Key Assumption appendix addition to Study and SAP **Pending**
- ✓ Cash Flow/Revenue Model addition to the Study

PRIORITY PROJECTS NEXT 2-3 MONTHS:

- Hurricane Risk Analysis
- ✓ Develop proforma with detailed rate analysis

PRIORITY PROJECTS NEXT 3-12 MONTHS:

- Sensitivity and Grid Analysis **Pending- IRP Manager Input**
- Business Case for City Owned Solar inside City Limits
- Electric Utility Strategic Plan **RFP out for bid**